

PALISADES PLANT
Docket 50-255

NRC FORM 365
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I P A L 1 2000-000000-000 3411111 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 L 605000255 7061083 8062383 9
7 8 9 REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During routine sampling of T-82C ("C" Safety Injection Tank), tank level
03 fell below the TS limit of 186 inches. T-82C level was not restored within
04 the one hour requirement of TS 3.3.2. exceeding the requirement by approx-
05 imately 2 minutes. Condition reportable per TS 6.9.2.a(2). No threat to
06 public health or safety resulted.
07
08

09 SF 11 E 12 B 13 A C C U M U 14 Z 15 Z 16
7 8 9 SYSTEM CODE 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 14 VALVE SUBCODE 15
17 83 041 01 T 0
7 8 9 LER/RO REPORT NUMBER 21 EVENT YEAR 22 SEQUENTIAL REPORT NO. 23 OCCURRENCE CODE 24 REPORT TYPE 25 REVISION NO. 26
X 18 X 19 Z 20 Z 21 0000 22 N 23 N 24 N 25 N150 26
7 8 9 ACTION TAKEN 33 EFFECT ON PLANT 34 SHUTDOWN METHOD 35 HOURS 36 ATTACHMENT SUBMITTED 37 NRC/RA FORM SUB. 38 PRIME COMP. SUPPLIER 39 COMPONENT MANUFACTURER 40

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 As part of the normal sampling process, the SIT is drained and refilled
11 with borated water. In this instance, fill operations were delayed when
12 the relief valve RV-3161 on the fill and drain header lifted and did not
13 reset before the 1 hour TS limit was exceeded. RV-3161 will be inspected
14 and repaired if necessary during the 1983 Refueling Outage.

15 E 28 1000 29 NA A 31 Alarm Annunciation 32
7 8 9 FACILITY STATUS 10 % POWER 11 OTHER STATUS 12 METHOD OF DISCOVERY 13 DISCOVERY DESCRIPTION 14
16 Z 33 Z 34 NA NA 36
7 8 9 ACTIVITY RELEASED 33 CONTENT OF RELEASE 34 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
17 000 37 Z 38 NA 39
7 8 9 PERSONNEL EXPOSURES NUMBER 37 TYPE 38 DESCRIPTION 39
18 000 40 NA 41
7 8 9 PERSONNEL INJURIES NUMBER 40 DESCRIPTION 41
19 Z 42 NA 43
7 8 9 LOSS OF OR DAMAGE TO FACILITY TYPE 42 DESCRIPTION 43
20 N 44 NA 45
7 8 9 PUBLICITY ISSUED 44 DESCRIPTION 45
7 8 9 NRC USE ONLY 68 69 80

8307050140 830623
PDR ADOCK 05000255
S PDR

1E22
1/1



Consumers
Power
Company

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

June 23, 1983

James G Keppler, Administrator
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - LICENSEE EVENT REPORT 83-41 - ("C" SAFETY INJECTION TANK
LOW LEVEL GREATER THAN ONE HOUR)

On the reverse please find Licensee Event Report 83-41 ("C" Safety Injection
Tank Low Level Greater Than One Hour), which is reportable to the NRC per
Technical Specification 6.9.2.a(2).

Brian D Johnson
Staff Licensing Engineer

CC Director, Office of Nuclear Reactor Regulation
Director, Office of Inspection and Enforcement
NRC Resident Inspector - Palisades

JUN 27 1983

JE 22
111