

ENCLOSURE

REVISED PAGES OF PROPOSED TECHNICAL SPECIFICATIONS

SEQUOYAH NUCLEAR PLANT
UNITS 1 AND 2

TVA-SQN-TS-48(R1)

INSTRUMENTATION

ACCIDENT MONITORING INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.7 The accident monitoring instrumentation channels shown in Table 3.3-10 shall be OPERABLE.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With the number of OPERABLE accident monitoring instrumentation channels, except for the RCS subcooling margin monitor, less than the Required Number of Channels shown in Table 3.3-10, restore the inoperable channel(s) to OPERABLE status within 7 days, or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE accident monitoring instrumentation channels less than the MINIMUM CHANNELS OPERABLE requirements of Table 3.3-10, restore the inoperable channel(s) to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.
- c. With the subcooling margin monitor inoperable for more than 48 hours, the minimum shift crew (per Table 6.2-1) will be increased by one member who shall be dedicated to and capable of determining the subcooling margin during an accident using existing instrumentation. *

SURVEILLANCE REQUIREMENTS

4.3.3.7 Each accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-7.

*With the RCS subcooling margin monitor inoperable for less than 2 hours, the provisions of section 6.9.1.13.b are not applicable.

INSTRUMENTATION

ACCIDENT MONITORING INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.7 The accident monitoring instrumentation channels shown in Table 3.3-10 shall be OPERABLE.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With the number of OPERABLE accident monitoring instrumentation channels, except for the RCS subcooling margin monitor, less than the Required Number of Channels shown in Table 3.3-10, restore the inoperable channel(s) to OPERABLE status within 7 days, or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE accident monitoring instrumentation channels less than the MINIMUM CHANNELS OPERABLE requirements of Table 3.3-10, restore the inoperable channel(s) to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.
- c. With the subcooling margin monitor inoperable for more than 48 hours, the minimum shift crew (per Table 6.2-1) will be increased by one member who shall be dedicated to and capable of determining the subcooling margin during an accident using existing instrumentation. *

SURVEILLANCE REQUIREMENTS

4.3.3.7 Each accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-7.

*With the RCS subcooling margin monitor inoperable for less than 2 hours, the provisions of section 6.9.1.13.b are not applicable.