

GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

July 19, 1984
5211-84-2181

Office of Nuclear Reactor Regulation
Attn: H. Denton, Director
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. T. E. Murley
Region I, Regional Admin.
U. S. Nuclear Regulatory Com.
631 Park Avenue
King of Prussia, PA 19406


Dear Sirs:

Three Mile Island Nuclear Station Unit I, (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Reactor Containment Building Integrated Leak Rate Test

Enclosed is the summary report entitled TMI-1 Reactor Containment Building Integrated Leak Rate Test concerning the Containment Integrated Leak Rate Test (ILRT) conducted in April, 1984. Reactor Building Local Leak Rate Test Reports found in appendices G, H, and I contain a summary and analysis of Type B and C tests performed since our last submittal of October 5, 1981. This is being submitted in accordance with Technical Specification Sections 4.4.1.1.8 and 6.9.3.A(3) and 10 CFR 50 Appendix J.

The low integrated leakage rate from the reactor containment building, approximately one-half of the allowable leakage rate, provides assurance that the reactor containment building is capable of performing its intended safety function.

Sincerely,


H. D. Hukill
Director, TMI-1

HDH/MRK/jrg

Enclosure

cc: R. Conte

8407260221 840719
PDR ADOCK 05000289
P PDR

Handwritten: A017
11