

Georgia Power Company
Route 2, Box 299A
Waynesboro, Georgia 30830
Telephone 404 554-9961, Ext. 3360
404 724-8114, Ext. 3360

D. O. Foster
Vice President and Project
General Manager
Vogtle Project



16 AUG 54

July 5, 1984

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

Reference:
RII: JPO:
50-424, 50-425

File: X7BC24
Log: GN-383

Attention: Mr. James P. O'Reilly

In our letter of June 26, 1984 (File: X7BC24, Log: GN-377), in response to I&E Bulletin 83-07, "Apparently Fraudulent Products Sold by Ray Miller, Inc." Georgia Power Company made the statement that "no materials supplied by Ray Miller, Inc. have been used in or provided for safety-related applications at the Vogtle Electric Generating Plant." This statement may appear to contradict information supplied in the investigation summary attached to the letter; therefore, Georgia Power Company wishes to make a point of clarification on this matter.

A ten foot section of Schedule 40 S/S 304L, 1-1/4 inch pipe from Ray Miller, Inc. was supplied to the Vogtle Electric Generating Plant by Modern Welding Company, Inc. in an Auxiliary Building sump lining assembly for a safety-related system. The sump lining assembly was scrapped for failure to meet specification requirements in May, 1979 (long before the Ray Miller issue was identified) and was never installed in the plant.

I hope this clarification precludes any misunderstanding of the intent of our response to I&E Bulletin 83-07. This letter contains no proprietary information and may be placed in the NRC Public Document Room.

Sincerely,

D. O. Foster

REF/DOF/tdm


8407260258 840705
PDR ADOCK 05000424
PDR
Q

10 IE 11


Mr. James P. O'Reilly
July 3, 1984
Page Two

D. O. Foster states that he is the Vice President and Project General Manager of the Vogtle Electric Generating Plant and is authorized to execute this oath on behalf of Georgia Power Company and that to the best of his knowledge and belief the facts set forth in this letter are true.

GPC:


D. O. Foster

Sworn to and subscribed before me this 4th day of July, 1984.


Notary Public
State of Georgia at Large
My Commission Expires: April 11, 1988

Attachment

xc: U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

O. Batum
J. A. Bailey
E. D. Groover
L. T. Gucwa
M. Malcom
G. Bockhold, Jr.
P. D. Rice
W. F. Sanders
W. T. Nickerson