

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
LaSalle County Station Unit 1DOCKET NUMBER (2)
050003713PAGE (3)
1 OF 03TITLE (4)
Scram on Low Reactor Water LevelEVENT DATE (5)
MONTH DAY YEAR
06 24 84

LER NUMBER (6)

REPORT DATE (7)

OTHER FACILITIES INVOLVED (8)

FACILITY NAMES
DOCKET NUMBER(S)
050003713OPERATING MODE (9)
1

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5 (Check one or more of the following) (11)

20.402(b)

20.405(c)

X 50.73(a)(2)(iv)

73.71(b)

POWER
LEVEL
(10)

0185

20.405(a)(1)(i)

50.36(a)(1)

50.73(a)(2)(v)

73.71(c)

20.405(a)(1)(ii)

50.36(c)(2)

50.73(a)(2)(vii)

OTHER (Specify in Abstract
below and in Text, NRC Form
366A)

20.405(a)(1)(iii)

50.73(a)(2)(i)

50.73(c)(2)(viii)(A)

20.405(a)(1)(iv)

50.73(a)(2)(ii)

50.73(a)(2)(viii)(B)

20.405(a)(1)(v)

50.73(a)(2)(iii)

50.73(a)(2)(x)

LICENSEE CONTACT FOR THIS LER (12)

NAME
R. D. Koenig, extension 499

TELEPHONE NUMBER

AREA CODE

8153571-167611

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE SYSTEM COMPONENT MANUFACTURER REPORTABLE TO NRC
X JBI MOD B045 Y

SUPPLEMENTAL REPORT EXPECTED (14)

EXPECTED
SUBMISSION
DATE (15)

MONTH DAY YEAR

YES (If yes, complete EXPECTED SUBMISSION DATE)

X NO

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On June 24, 1984, at 0820 hours, the Unit 1 Reactor scrambled on low vessel level. The unit was at 85% power. All indications show that the main steam flow signal to the Reactor Water Level Control (JB) logic was lost. This resulted in the feedwater flow going to zero. With feedwater flow shut down, vessel level dropped to 12.5 inches, producing a scram on low level. The loss of steam flow was linked to the steam flow summer or dynamic compensator. One of these devices stopped operating. This produced a zero steam flow signal to the Reactor Water Level Control logic (JB). The result was a zero feedwater flow demand. The cause of the momentary loss of signal could not be determined.

8407260346 840718
PDR ADOCK 05000373
S PDR

IE 22

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO 3150-0104
EXPIRES 8/31/85

FACILITY NAME (1) LaSalle County Station Unit 1	DOCKET NUMBER (2) 0-500037384-	LER NUMBER (8)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		039	010	02	OF	03	

TEXT (If more space is required, use additional NRC Form 308A's) (17)

I. EVENT DESCRIPTION

On June 24, 1984, at 0820 hours, the Unit 1 Reactor scrambled on low vessel water level. The unit was operating at 85% power when the feedwater system (FW, SJ) received a signal from its Reactor Water Level Control (RWLC, JB) logic to reduce flow rate to zero. This caused vessel level to drop, and at 12.5 inches produced a reactor scram (level dropped to -5 inches level).

II. CAUSE

The cause of the Unit 1 Reactor scram was attributed to the feedwater flow rate reducing to zero. This caused vessel level to decrease, finally scrambling the unit due to low vessel level.

In normal operating conditions, the reactor water level control (RWLC) logic receives three parameters: main steam flow, feedwater flow, and vessel level (three elements). These three parameters are manipulated by the RWLC logic to produce a feedwater demand signal. Of the three elements, the main steam flow signal was lost, apparently due to a flow summer or dynamic compensator problem.

With steam flow essentially dropping to zero (as seen by the RWLC logic) the feedwater demand signal dropped to zero. Feedwater Turbine Driven Reactor Feed Pumps (TDRFP's) 1A and 1B saw a zero demand signal so feedwater flow was reduced accordingly. With feedwater flow reduced to nothing, vessel level began dropping (due to steam production). When vessel level reached the 12.5 inch level the reactor automatically scrambled.

It is surmised that the output of either the flow summer or dynamic compensator used for monitoring steam flow in the RWLC logic dropped to zero. (The reason could not be determined.) This produced the false "zero" main steam flow signal. The reason for the summer or compensator problem could not be determined.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

The consequences of this event were minimal. With feedwater flow reduced to zero, and vessel level dropping to 12.5 inches, the low water level instrumentation initiated a reactor scram. Had the vessel water level continued to drop, the Emergency Core Cooling systems would have actuated, as required.

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

FACILITY NAME (1) LaSalle County Station Unit 1	DOCKET NUMBER (2) 0-5100037384-039-01003 OF 03	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		

TEXT (If more space is required, use additional NRC Form 365A's) (17)

IV. CORRECTIVE ACTION

LaSalle Station Work Request L38185 was written to investigate this problem further. Since the time of this event, signals from the RWLC logic (steam flow transmitter output, steam flow summer output, dynamic compensator input, FW flow transmitter output, and A/B TDRFP flow) have been monitored. No major problems in the logic have been identified. The logic is operating, as required, with no problems encountered. LIP-FW-03 was performed on the steam flow transmitters, with no problems found.

The Unit 1 FW system was started up in single element. With no problems found, three-element operation is now being used.

V. PREVIOUS OCCURRENCES

No previous occurrences of this type have occurred as of this date.

VI. NAME AND TELEPHONE NUMBER OF PREPARER

R. D. Koenig, 815/357-6761, extension 499.



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

July 18, 1984

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #84-039-00, Docket #050-373 is being submitted to your office in accordance with 10 CFR 50.73.

C E Dargatz

G. J. Diederich
Superintendent
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director
INPO-Records Center
File/NRC

IE22
1/1