

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH May, 1984
Revised July, 1984

DOCKET NO. 50-244
UNIT NAME #1, Ginna Station
DATE July, 1984
COMPLETED BY Andrew E. McNamara
TELEPHONE (315)-524-4446 Ext. 301
at Ginna

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
84-2	5/14/84	* F	* 207.75	A	1	N/A	HF	Secondary Chemistry	Condensate Bypass valve 90° out of phase, bypassing AVT. Secondary chemistry out of specs, crevice cleaning and sludge lancing on S/G A & B, and condenser tube leak.
84-3	5/23/84	S	6.75	B	1	N/A	N/A	N/A	T-18C, Turbine Overspeed Trip Test- This shutdown was extended due to an exciter cooler leak.
84-4	5/30/84	F	57.50*	A	3	N/A	HA	Exciter Failure	Air cooler gasket, poor compression. Shimmed air cooler to provide proper alignment and sealant on both sides.
*NOTE: This shutdown ended on 6/2/84. Forced outage hours used to calculate the forced outage rate for this report period are hours in May only.									

*Revised
1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source