

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 FILITPIS 13 20 00 - 00 00 00 - 00 00 34 11 11 11 4 5
 7 8 9 14 15 25 26 30 37 38 39

CON'T
 01 REPORT SOURCE L 5 0 5 0 0 0 2 5 0 7 0 1 5 1 1 8 2 8 0 7 2 1 3 8 4 9
 7 8 9 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
 02 Inadequate surveillance testing of the Emergency Diesel Generators (EDG) was
 03 performed between 5/11/82 and 6/7/84 for tests required by Technical
 04 Specification (TS) 4.8.1.a.6 and 4.8.1.C.6(C), 14 day and 18 month tests,
 05 respectively, in that insufficient data were recorded to verify satisfactory
 06 performance of the EDG cooling system. During this time interval, the EDG
 07 did not exhibit inadequate functioning of the cooling system. This is
 08 reportable pursuant to TS 6.9.2.6.3.

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
 10 E E 11 D 12 Z 13 Z Z Z Z Z Z 14 Z 15 Z 16
 17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 18 8 2 19 0 2 0 20 0 3 21 L 22 0
 23 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER
 24 G 25 X 26 Z 27 Z 28 0 0 0 0 29 Y 30 N 31 Z 32 Z 33 9 34 9 35 9 36 9 37 9 38 9 39 9 40 9 41 9 42 9 43 9 44 9 45 9 46 9 47 9 48 9 49 9 50 9 51 9 52 9 53 9 54 9 55 9 56 9 57 9 58 9 59 9 60 9 61 9 62 9 63 9 64 9 65 9 66 9 67 9 68 9 69 9 70 9 71 9 72 9 73 9 74 9 75 9 76 9 77 9 78 9 79 9 80 9 81 9 82 9 83 9 84 9 85 9 86 9 87 9 88 9 89 9 90 9 91 9 92 9 93 9 94 9 95 9 96 9 97 9 98 9 99 100

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
 10 The root cause stems from an inadequate review of operating Procedure 4304.1.
 11 EDG Periodic Test Load on 4KV Bus & 4304.3, EDG-Eight Hour Full Load Test and
 12 Load Rejection with regard to implementation of TS amendments 82/76 issued
 13 4/5/82, which upgraded EDG surveillance test requirements to verify satisfac-
 14 tory performance of the EDG cooling system. The procedures have been revised.

15 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
 16 E 28 10 10 29 N/A 30 L C 31 Document Review 32
 17 ACTIVITY CONTENT RELEADED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
 18 Z 33 Z 34 N/A 35 N/A 36
 19 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
 20 0 0 0 37 Z 38 N/A 39
 21 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
 22 0 0 0 40 N/A 41
 23 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
 24 Z 42 N/A 43
 25 PUBLICITY ISSUED DESCRIPTION (45)
 26 N 44 N/A 45

NAME OF PREPARER P.A. Roach/R.D. Hart PHONE: 305/245-2910x-353

8407270355 840723
PDR ADOCK 050J0250
S PDR

IE22
1/1

Additional Event Description and Probable Consequences

The health and safety of the public were unaffected. Similar occurrences:
LER 250-82-021.

Additional Cause Description and Corrective Actions

The procedures have been revised to clearly reflect the TS requirements and satisfactory EDG testing to the TS requirements completed.

The following corrective action has been taken to preclude recurrence:

Procedure changes have been implemented which address a system of administrative controls to ensure proper plant review, approval and implementation of license amendments and/or technical specification changes.



July 23, 1984
PNS-LI-84-252

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

Re: Reportable Event 82-20
Turkey Point Unit 3
Date of Event: May 11, 1982
Emergency Diesel Generator Surveillance

The attached Licensee Event Report is being submitted pursuant to the former requirements of Technical Specification 6.9 to provide notification of the subject event. This event was not determined to be reportable until June 21, 1984.

Very truly yours,

A handwritten signature in dark ink, appearing to read "J. W. Williams, Jr.", written in a cursive style.

J. W. Williams, Jr.
Group Vice President
Nuclear Energy

JWW/PLP/js

Attachment

cc: J. P. O'Reilly, Region II, USNRC
Harold F. Reis, Esquire
File 933.1

IE22
1/1