



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

July 13, 1984
(NMP2L 0109)

Mr. R. W. Starostecki, Director
U.S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim report in accordance with 10CFR50.55(e) for the problem concerning the main steam isolation valves furnished by Gulf & Western/Fluid Systems Division. This problem was reported via telecon to Mr. S. Collins of your staff on June 15, 1984.

Very truly yours,

C. V. Mangan
Vice President
Nuclear Engineering & Licensing

TL:ja
Enclosure
xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

R. A. Gramm, Resident Inspector

Project File

8407270378 840713
PDR ADOCK 05000410
S PDR

1E 27

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT - UNIT 2
DOCKET NO. 50-410

Interim Report for a Problem
Concerning the Main Steam Isolation Valves
(55(e)-84-23)

Problem Description

During a review of documentation, it was observed that the certified material test reports (CMTRs) provided by the valve manufacturer do not document the test coupon heat treatment duration and temperature as required by ASME Section III, NB-2211. Further inquiry revealed that the heat treatment of the test coupons was not performed. A final report will be issued by October 14, 1984.