

1801 Chestnut Avenue
Post Office Box 143
St. Louis, Missouri 63106
314-621-3222



March 11, 1992

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Gentlemen:

ULNRC-2585

DOCKET NUMBER 50-483
CALLAWAY PLANT
AMENDMENT NUMBER 66

This is to inform the Commission of the implementation of Amendment No. 66 to the Callaway Facility Operating License No. NPF-30. Amendment No. 66 approved a Technical Specification change to revise the maximum allowable leakage rate of the reactor coolant pressure isolation valves. The changes have been issued to all controlled Technical Specification holders and became effective on January 24, 1992.

Very truly yours,

A. C. Passwater
Manager, Licensing and
Fuels

WEK/plh

*Accol
11/0*

cc: T. A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Dr. J. O. Cermak
CFA, Inc.
18225-A Flower Hill Way
Gaithersburg, MD 20879-5334

R. C. Knop
Chief, Reactor Project Branch 1
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Bruce Bartlett
Callaway Resident Office
U.S. Nuclear Regulatory Commission
RR#1
Steedman, Missouri 65077

L. R. Wharton (2)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop 13E21
11555 Rockville Pike
Rockville, MD 20852

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

Ron Kucera
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102