



231 W. Michigan, P.O. Box 2046, Milwaukee, WI 53201

(414) 224-2345

VPNPD-92-104

March 6, 1992

State of Wisconsin  
DEPARTMENT OF NATURAL RESOURCES  
WPDES Permit Section  
Post Office Box 7921  
Madison, Wisconsin 53707

Gentlemen:

WPDES PERMIT WI-2000357-4  
POINT BEACH NUCLEAR PLANT

This is to notify you that the daily maximum total residual chlorine effluent limitation was exceeded at Point Beach Nuclear Plant. The total residual chlorine concentration in the Unit 1 cooling water discharge (outfall 001) was 0.71 mg/l on March 4, 1992.

We have commenced an investigation into this incident. When the investigation is completed, a letter will be sent to the DNR outlining the results of the investigation and corrective action, if any, which has been, or will be, taken.

Sincerely,

A handwritten signature in cursive script, appearing to read 'James J. Zach'.

James J. Zach  
Vice President  
Nuclear Power

Copies to DNR Lake Michigan District  
NRC Document Control Desk  
NRC Regional Administrator, Region III

120013  
9203170316 920306  
PDR ADDOCK 05000266  
S PDR

COPI 1/0