

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

BLRD-50-438/83-56 MAY 18 8:48 May 15, 1984
BLRD-50-439/83-49

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - MASS OF HVAC SUPPORTS NOT INCLUDED
IN FREQUENCY CALCULATIONS - BLRD-50-438/83-56, BLRD-50-439/83-49 - SECOND
INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector
P. E. Fredrickson on October 20, 1983 in accordance with 10 CFR 50.55(e) as
NCR BLN BLP 8336. This was followed by our interim report dated
November 18, 1983. Below is our second interim report. We expect to
submit our next report by February 5, 1985.

TVA is still in the process of investigating the subject deficiency. A
review of calculations for duct supports in safety-related systems is
continuing. Of approximately 600 duct supports in the Reactor Building
that have been reviewed, only two required field modifications.

If you have any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

D S Kammer

for L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8405240042 840515
PDR ADOCK 05000438
S PDR