

RP



Georgia Power

the southern electric system

Vogtle Project

3 All: 23

May 1, 1984

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

File: X7BG03-M54
Log: GN-354

Reference: Vogtle Electric Generating Plant-Units 1 and 2, 50-424, 50-425;
Pacific Scientific Shock Arrestors, GPC letter GN-321 dated 2/23/84

Attention: Mr. James P. O'Reilly

Gentlemen:

In our previous correspondence on this issue, Georgia Power Company indicated that we did not have a test schedule for our snubbers and that we would advise the NRC on or about May 18, 1984, when a final report on this issue could be expected.

At this time, Georgia Power Company is forecasting a completion date of July 20, 1984, for the final report to the NRC on this issue. On this date, Georgia Power Company will advise the NRC if this issue has been concluded to represent a reportable deficiency.

Georgia Power Company had received one hundred and fifty-one (151) shock arrestors of sizes PSA-1 and PSA-3 at the construction site. These units were returned to Pacific Scientific for testing on January 6, 1984. These units have been tested, the defective capstan springs have been replaced, and the reassembled units have been tested and reshipped to the construction site. The attached pages identify the shock arrestors of each type (PSA-1 and PSA-3) which were found to contain deficient springs. These units are included in the final engineering evaluation which is in progress.

This letter contains no proprietary information and may be placed in the NRC Public Document Room.

Yours truly,

D. O. Foster

REF/DOF/tdm

xc: U. S. Nuclear Regulatory Commission, Document Control Desk, Washington, D.C.

R. J. Kelly
R. E. Conway
G. F. Head
C. W. Hayes
D. M. MacLemore

D. E. Dutton
W. F. Sanders
R. H. Pinson
P. D. Rice
R. A. Thomas

J. A. Bailey
O. Batum
G. Bockhold
B. M. Guthrie
E. D. Groover

L. T. Gucwa
M. Malcom
H. H. Gregory, III
J. T. Beckham, Jr.
J. L. Vota

OFFICIAL COPY

84-29-11
TE 22-11

PACIFIC-SCIENTIFIC
PSA-1 AND PSA-3 SNUBBERS

Capstan Springs Replaced

PSA-1

<u>Serial No.</u>	<u>Pipe Support No.</u>
20172	V1-1206-006-H020
20173	V2-1205-009-H009
20355	V2-1205-003-H009
21662	V2-1305-081-H002
21663	V2-1305-081-H002
21664	V1-1202-002-H010
21665	V2-1204-007-H005
21668	V2-1204-038-H003
21670	V1-1202-072-H005
21672	V1-1407-004-H023
21673	V1-1407-001-H020
21674	V1-1202-184-H003
21677	V2-1205-010-H012
21678	V2-1301-010-H021
21680	V1-1205-008-H041
21682	V1-1208-003-H044
21683	V1-1205-007-H062
21684	V2-1205-007-H046
21900	V1-1217-025-H003
21901	V1-1204-057-H021
22316	V2-1204-192-H002

Capstan Springs Replaced

PSA-3

<u>Serial No.</u>	<u>Pipe Support No.</u>
25370	V1-1202-072-H018
25375	V1-1202-181-H025
25376	V1-1202-004-H047
25381	V1-1407-004-H021
25382	V1-1204-042-H018
25501	V2-1206-006-H003
25502	V2-1202-006-H023
25503	V1-1202-004-H050
24693	V1-1202-088-H014
24696	V1-1202-104-H030
24698	V1-1205-010-H016
24700	V1-1205-010-H017
24701	V1-1202-006-H026
24704	V1-1203-063-H001
24705	V1-1202-088-H028
24706	V1-1202-151-H049
24708	V1-1202-134-H036
24709	V1-1203-021-H008
25051	V1-1205-027-H004
25366	V1-1407-002-H018
27246	V2-1206-055-H009
27250	V1-1201-064-H021
27252	V1-1305-110-H043
27262	V2-1206-007-H045