

Arizona Public Service Company

May 14, 1984
ANPP-29494-TDS/TRB

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Time Extension For Report - DER 83-78
A 50.55(e) Potentially Reportable Deficiency Relating To No
Documentation Of Users Test And No Controlling Procedure For
Rock Bolt Expansion Anchors.
File: 84-019-026; D.4.33.2

Reference: (A) Telephone conversation between P. Narbut and K. Parrish on
November 9, 1983.
(B) ANPP-28393, dated December 8, 1983 (Interim Report)
(C) ANPP-28801, dated February 6, 1984 (Time Extension)


Dear Sir:

The NRC was notified of a potentially reportable deficiency in
Reference (A), and an Interim Report was transmitted by Reference (B).
At that time, it was estimated that a Final Report would be available by
May 16, 1984.

Due to the extensive investigation and evaluation required, it is now
expected that this information will be finalized by June 15, 1984, at
which time a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,


E. E. Van Brunt, Jr.
APS Vice President, Nuclear
ANPP Project Director

EEVB/TRB:db

cc: See Page Two

8405240253 840514
PDR ADOCK 05000528
S PDR

1E-2711

Mr. T. W. Bishop
DER 83-78
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
D. B. Karner
W. E. Ide
D. B. Fasnacht
A. C. Rogers
B. S. Kaplan
L. A. Souza
D. E. Fowler
J. Vorees
J. R. Bynum
J. M. Allen
P. P. Klute
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
H. D. Foster
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
S. R. Frost
J. Self
D. Canady

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339