



NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

January 22, 1974

Mr. James G. Keppler
Regional Director
United States Atomic Energy Commission
Directorate of Regulatory Operations
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr. Keppler:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

The Directorate of Regulatory Operations Bulletin No. 74-1 requested that we determine if valves similar to those discussed in the Bulletin are installed or scheduled to be installed in the Monticello Nuclear Generating Plant. These valves are identified as 12 inch - 300 pound motor operated globe valves manufactured by the Walworth Company and specific 2 inch gate valves manufactured by the Darling Valve and Manufacturing Company.

Equipment records for Monticello have been reviewed and it was determined that (1) there are no 2 inch valves manufactured by the Darling Valve and Manufacturing Company installed or scheduled to be installed in the plant and (2) there are no 12 inch - 300 pound motor operated globe valves manufactured by the Walworth Company installed or scheduled to be installed in the plant. Item (2) can be further qualified in that the only Walworth Company valves installed in the plant are a 10 inch check valve and several 2 1/2 inch gate valves.

Yours very truly,

L J Wachter, Vice President
Power Production & System Operation

LJW/ts

cc: ✓ B H Grier, Directorate of Regulatory Operations
J F O'Leary, Directorate of Licensing
G Charnoff
Minnesota Pollution Control Agency - Attn: E A Pryzina

JAN 24 1974

9102110275 740122
PDR ADOCK 05000263
G PDR