

Interim Notification of a
Potentially Reportable
Issue Pursuant to 10CFR21

Date: 16 March 1992

To: U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Ref: TU Electric
Comanche Peak Steam
Electric Station
10CFR21 Report P21R-92-001

DESCRIPTION:

On 16 January 1992, BW/IP was notified by TU Electric of a reportable deficiency involving check valve P/N 72543 (swing arm) on Borg-Warner Model No. 75510 3" - 900 lb. swing check valve.

BW/IP has evaluated the reported defect and concludes the replacement swing arm is equivalent in fit, form, and function to the original part.

P/N 72543 (swing arm) is used in other valve sizes. BW/IP has identified these valves and is evaluating whether a reportable deficiency exists.

ADDITIONAL ACTIONS PLANNED:

BW/IP evaluation will be completed no later than 16 June 1992.

VENDOR CONTACT:

Kent A. Huber
Part 21 Evaluation Board Chairman