

Duke Power Company
McGuire Nuclear Generation Department
12700 Hagers Ferry Road (MG01A)
Huntersville, NC 28078-8985

T. C. McMEekin
Vice President
(704)875-4800
(704)875-4809 FAX



DUKE POWER

March 12, 1992

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: McGuire Nuclear Station
Docket Nos. 50-369, -370
Inspection Report No. 50-369, -370/91-01

Gentlemen:

In our letter of March 20, 1991, transmitting our response to Violation 369, 370/91-01-03, the corrective action to be taken consisted of a program to inspect all safety and non-safety related electrical cabinets containing fuses. The date given for the completion of this inspection was the completion of the Unit 2 end of Cycle 7 outage.

There are approximately 450 safety related cabinets and 2000 non-safety related cabinets to be inspected. Due to the magnitude of this inspection program, we would like to change this commitment to complete the inspection of only the safety related cabinets by the end of the Unit 2 end of Cycle 7 outage.

The inspection of the non-safety related cabinets will continue until the initial inspection is completed. After the initial inspection of all cabinets, further inspections of both safety and non-safety related cabinets will be scheduled through the Periodic Maintenance program.

Should there be any questions concerning this matter, contact Larry Kunka at (704)875-4032.

Very truly yours,

T. C. McMeekin
McGuire Nuclear Site Vice President

LJK/cbl

9203250076 920312
PDR ADOCK 05000369
G PDR

7201 1/0

XC1

Mr. S. D. Ebnetter
Administrator, Region II
U.S. Nuclear Regulatory Commission
1001 Marietta St., NW, Suite 2900
Atlanta, GA 30323

Mr. Tim Reed
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

Mr. P. K. Van Doorn
NRC Resident Inspector
McGuire Nuclear Station

bxc1

A.V. Carr - PB05E
T. Lynch
R.C. Futrell (CNS)
R.L. Gill
P.R. Herran
M.E. Patrick (ONS)
R.O. Sharpe
D.R. Bradshaw
M.A. Mullen
T.L. Pedersen
T.S. Barr
QA Tech. Service NRC Coordinator (EC12A)
M.F. 1.2.1
File MC 815.01