



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640 JACKSON, MISSISSIPPI 39205

84 MAY 21

12:00

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

May 15, 1984

U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 2
Docket No. 50-417
License No. NPF-13
File 0260/15525/15526/16694.4
PRD-83/10, Final Report for Unit 2,
ASCO Spare Parts Kits for Scram
Pilot Valve Solenoids
AECM-84/2-0004

References: AECM-83/0445, 8/5/83
AECM-83/0561, 9/9/83
AECM-83/0596, 9/16/83

On August 4, 1983, and September 16, 1983, Mississippi Power & Light Company notified Mr. Paul Fredrickson and Ms. L. Watson, respectively, of your office, of two Reportable Deficiencies at the Grand Gulf Nuclear Station (GGNS) which MP&L had evaluated and determined to be reportable under the provisions of 10CFR21 for Unit 1. These deficiencies concerned the receipt and installation of improperly assembled ASCO spare parts kits for the scram pilot valves.

This deficiency has been investigated and has been determined to be not applicable to Unit 2 since no field maintenance utilizing these spare parts kits has been performed on Unit 2 and no ASCO kits were purchased as spares for use on Unit 2.

Yours truly,

KDS
KDS:dr
cc: See page 2

8405290109 840515
PDR ADDCK 05000417
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 19 1/0

Mr. J. P. O'Reilly
NRC

AECM-84/2-0004
Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. Nicholas S. Reynolds, Esq.
Bishop, Liberman, Cook, Purcell & Reynolds
1200 Seventeenth Street, N. W.
Suite 700
Washington, D. C. 20036

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. G. B. Taylor
South Miss. Electric Power Association
P. O. Box 1589
Hattiesburg, MS 39401