

ATTACHMENT 2

REVISED TECHNICAL SPECIFICATION

9203250151 920319
PDR ADOCK 05000313
P PDR

6.12.3 CORE OPERATING LIMITS REPORT

6.12.3.1 The core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT prior to each reload cycle or prior to any remaining part of a reload cycle.

6.12.3.2 The analytical methods used to determine the core operating limits addressed by the individual Technical Specification shall be those previously reviewed and approved by the NRC for use at ANO-1, specifically:

1. Babcock & Wilcox Topical Report BAW-10122A Rev. 1, "Normal Operating Controls," May 1984.
2. Babcock & Wilcox Topical Report BAW-10116-A "Assembly Calculations and Fitted Nuclear Data," May 1977.
3. Babcock & Wilcox Topical Report BAW-10117P-A, "Babcock & Wilcox Version of PDQ User's Manual," January 1977.
4. Babcock & Wilcox Topical Report BAW-10118A, "Core Computational Techniques and Procedures," December 1979.
5. Babcock & Wilcox Topical Report BAW-10123A, "FLAME 3-A Three-Dimensional Nodal Code for Calculating Core Reactivity and Power Distributions," August 1976.
6. Babcock & Wilcox Topical Report BAW-10125A, "Verification of Three-Dimensional FLAME Code," August 1976.
7. Babcock & Wilcox Topical Report BAW-10119P-A, "Power Peaking Nuclear Reliability Factors," February 1979.
8. Babcock & Wilcox, Topical Report BAW-10103A, Rev. 3, "ECCS Analysis of B&W's 177-FA Lowered Loop NSS," July 1977.
9. Babcock & Wilcox, Topical Report BAW-10162P-A, "TACO3 Fuel Pin Thermal Analysis Computer Code," November 1989.
10. Babcock & Wilcox, Report BAW-1915PA, "Bounding Analytical Assessment of NUREG-0630 Models on LOCA kW/ft Limits With Use of FLECSSET," November 1988.
11. Babcock & Wilcox, Topical Report BAW-10104PA Revision 5, "B&W ECCS Evaluation Model," November 1988.

6.12.3.3 The core operating limits shall be determined so that all applicable limits (e.g. fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.

6.12.3.4 The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance for each reload cycle to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.