


**NSP**

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

November 21, 1973

Mr. J F O'Leary, Director  
Directorate of Licensing  
Office of Regulation  
U S Atomic Energy Commission  
Washington, D C 20545



Dear Mr. O'Leary:

MONTICELLO NUCLEAR GENERATING PLANT  
Docket No. 50-263 License No. DPR-22

Inadvertent Omission of Required Surveillance Test

A condition occurred at the Monticello Nuclear Generating Plant which we are reporting to your office in accordance with Section 6.7.B.1, Abnormal Occurrence Reports, of Appendix A Technical Specifications of Provisional Operating License DPR-22.

On November 13, 1973, during a review of completed surveillance tests, it was discovered that the daily Linear Heat Generation Rate Surveillance Tests had not been completed for the date of November 9, 1973. Subsequent discussion with the operating personnel and examination of the control room log revealed the tests in question had inadvertently been omitted on November 9, 1973. A review of computer data for the date in question revealed that neither of the parameters monitored by the surveillance tests had exceeded Technical Specification limits.

Corrective action consisted of appending the subject surveillance tests to the previously existing Daily Surveillance Test Log thus ensuring distribution to the operating personnel. Additional corrective action will include a review of the process for controlling the distribution and use of the daily surveillance test procedures.

There have been no similar occurrences of omitting regularly scheduled surveillance tests at the Monticello Nuclear Generating Plant.

Yours very truly,

*L. O. Mayer*

L O Mayer, PE  
Director of Nuclear Support Services

LOM/br

cc: J G Keppler  
G Charnoff  
Minnesota Pollution Control Agency  
Attn Ken Dzigan

9105090415 731121  
PDR ADOCK 05000263  
S PDR

148

AEC DISTRIBUTION FOR PART 50 DOCKET # ERIAL  
(TEMPORARY FORM)

CONTROL NO: 8448

FILE:

FROM: Northern States Power Company Minneapolis, Minnesota 55401 L. O. Mayer			DATE OF DOC 11-21-73	DATE REC'D 11-26-73	LTR X	MEMO	RPT	OTHER
TO: J. F. O'Leary			ORIG 1 signed	CC	OTHER	SENT AEC PDR <u>X</u> SENT LOCAL PDR <u>X</u>		
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 40		DOCKET NO: 50-263		

DESCRIPTION:

Ltr reporting an abnormal occurrence on 11-13-73, in which it was discovered that the daily Linear Heat Generation Rate Surveillance Tests had not been completed for the date of 11-9-73

ENCLOSURES:

ACKNOWLEDGED

PLANT NAME: Monticello

DO NOT REMOVE

FOR ACTION/INFORMATION

11-26-73 GC

BUTLER(L)	SCHWENCER(L)	<del>ZIEMANN</del> (L)	REGAN(E)
W/ Copies	W/ Copies	W/7 Copies	W/ Copies
CLARK(L)	STOLZ(L)	DICKER(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
GOLLER(L)	VASSALLO(L)	KNIGHTON(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
KNIEL(L)	SCHEMEL(L)	YOUNGBLOOD(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

<u>REG FILE</u>	<u>TECH REVIEW</u>	DENTON	<u>LIC ASST</u>	<u>A/T IND</u>
✓AEC PDR	✓HENDRIE	GRIMES	✓DIGGS (L)	BRAITMAN
✓OGC, ROOM P-506A	✓SCHROEDER	GAMMILL	GEARIN (L)	SALTZMAN
✓MUNTZING/STAFF	✓MACCARY	KASTNER	GOULBOURNE (L)	B. HURT
✓CASE	✓KNIGHT	BALLARD	LEE (L)	<u>PLANS</u>
GIAMBUSSO	✓PAWLICKI	SPANGLER	MAIGRET (L)	MCDONALD
BOYD	✓SHAO		SERVICE (L)	DUBE
MOORE (L)(BWR)	✓STELLO	<u>ENVIRO</u>	SHEPPARD (E)	<u>INFO</u>
DEYOUNG(L)(PWR)	✓HOUSTON	MULLER	SMITH (L)	C. MILES
✓SKOVHOLT (L)	✓NOVAK	DICKER	TEETS (L)	✓B. KING (RO)
P. COLLINS	✓ROSS	KNIGHTON	WADE (E)	
<u>REG OPR</u>	✓IPPOLITO	YOUNGBLOOD	WILLIAMS (E)	
✓FILE & REGION(3)	✓TEDESCO	REGAN	WILSON (L)	
✓MORRIS	✓LONG	PROJECT LDR		
✓STEELE	✓LAINAS			
	✓BENAROYA	HARLESS		
	✓VOLLMER			

EXTERNAL DISTRIBUTION

✓1 - LOCAL PDR Minneapolis, Minn.	(1)(2)(10)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
✓1 - DTIE(ABERNATHY)	1-ASLEP(E/W Bldg, Rm 529)	1-GERALD LELLOUCHE
✓1 - NSIC(BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	BROOKHAVEN NAT. LAB
1 - ASLB(YORE/SAYRE/	1-CONSULTANT'S	1-AGMED(Ruth Gussman)
WOODARD/"H" ST.	NEWMARK/BLUME/AGBABIAN	RM-B-127, GT.
✓16 - CYS ACRS <del>XXXXXXXX</del> SENT TO LIC. ASS'.	1-GERALD ULRIKSON...ORNL	1-RD..MULLER..F-309 GT
11-26-73 Diggs		