



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN

VICE PRESIDENT
NUCLEAR

Mr. James G. Keppler
Regional Administrator, Region III
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

May 15, 1984

PRINCIPAL STAFF			
✓ SA	✓ DE	✓ DPRP	✓ ring + 1
✓ D/RA	✓ DE	✓	✓
✓ A/RA	✓	✓ DR1SP	✓
✓ RC	✓	✓ DRMA	✓
✓ PAO	✓	✓ SCS	✓
✓ GA	✓	✓ ML	✓
✓ E	✓	✓ File	✓

RE: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Use of Non-Class 1E Control Power
and Control Components in Diesel
Generator Building Ventilation
Systems [RDC 80(83)]

Dear Mr. Keppler:

Our letter to you dated March 15, 1983, stated that final field rewiring for diesel generator building ventilation start signals was expected to be completed by May 15, 1984.

Vendor supplied drawings necessary for issuance of the Engineering Change Notice to transfer this start signal to a safety-related circuit that contains only safety-related components were received. However, the Engineering Change Notice necessary to provide the design modification for initiating the start signal from a diesel generator control panel is now expected on site by May 21, 1984.

We now anticipate completion of final field rewiring by June 15, 1984.

Sincerely,

Murray R. Edelman

Murray R. Edelman
Vice President
Nuclear Group

MRE:pab

cc: Mr. M. L. Gildner
NRC Site Office

Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

Records Center, SEE-IN
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8405290312 840515
PDR ADOCK 05000440
S PDR

MAY 18 1984

IE27
1/0