

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

MAY 25 1984

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Nos.: 50-352
50-353

Subject: Limerick Generating Station, Units 1&2
Information for Containment Systems
Branch (CSB) Regarding SER Confirmatory
Issue #19 (Procedures for Isolating
Feedwater Bypass Lines).

Reference: Procedure No. GP-2, Revision 0:
Procedures for Normal Plant Startup

File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:

We are pleased to offer the following confirmatory
information in support of the resolution of SER confirmatory
issue #19.

The reference procedure provides the following note,
after step 3.3.16, to ensure that the remote-manual
motor-operated valves on the feedwater bypass lines are
isolated once the reactor pressure reaches 600 psig during
plant heatup and pressurization to rated temperature and
pressure:

"Ensure feedwater startup flush valves HV-41-109A
(209A) and 109B (209B) are closed whenever reactor
pressure is above 600 psig".

Should any additional information be required, please
do not hesitate to contact us.

Sincerely,

John S. Kemper

JHA/gra/052184600

cc: See Attached Service List

8405300392 840525
PDR ADOCK 05000352
E PDR

Boo!
1/0

cc: Judge Lawrence Brenner
Judge Richard F. Cole
Troy B. Conner, Jr., Esq.
Ann P. Hodgdon, Esq.
Mr. Frank R. Romano
Mr. Robert L. Anthony
Charles W. Elliot, Esq.
Zori G. Ferkin, Esq.
Mr. Thomas Gerusky
Director, Penna. Emergency
Management Agency
Angus R. Love, Esq.
David Wersan, Esq.
Robert J. Sugarman, Esq.
Spence W. Perry, Esq.
Jay M. Gutierrez, Esq.
Atomic Safety & Licensing
Appeal Board
Atomic Safety & Licensing
Board Panel
Docket & Service Section
Martha W. Bush, Esq.
Mr. James Wiggins
Mr. Timothy R. S. Campbell
Ms. Phyllis Zitzer
Judge Peter A. Morris