

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

March 27, 1992

U. S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, D.C. 20555

Serial No. 92-193
NL&P/TAH: RO
Docket Nos.: 50-339
License Nos.: NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT 2
SECOND TEN YEAR INSERVICE INSPECTION INTERVAL
REVISED ISI PROGRAM AND PLAN

Virginia Electric and Power Company has revised the North Anna Unit 2 Inservice Inspection Program and Plan to incorporate the requirements of ASME Section XI, 1986 Edition, for Category C-F-2 piping welds. In addition, we have revised our previous response to Item "E" of your request for additional information, dated August 5, 1991. The revised response is included as Attachment 1 and the Inservice Inspection Program and Plan for the Second Inspection Interval is Attachment 2.

If you have any further questions, please contact us.

Very truly yours,



W. L. Stewart
Senior Vice President - Nuclear

Attachment

cc: U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 2900
Atlanta, Georgia 30323

Mr. M. S. Lesser
NRC Senior Resident Inspector
North Anna Power Station

A047
11

ATTACHMENT 1

REVISED RESPONSE TO THE AUGUST 5, 1991
REQUEST FOR ADDITIONAL INFORMATION - ITEM "E"

NORTH ANNA POWER STATION
UNIT 2

VIRGINIA ELECTRIC AND POWER COMPANY

REVISED RESPONSE TO THE AUGUST 5, 1991
REQUEST FOR ADDITIONAL INFORMATION - ITEM "E"

E) NRC: Request for Relief NDE-7: Please provide clarification on the proposed alternative examination. Should the alternative read, "...associated with 'each' branch connection welds..." instead of "...associated with 'one' branch connection weld..."?

VEPCO: The selection of piping welds per Category C-F-2 of the 1986 Edition of ASME Section XI provides for more than one branch connection weld to be examined. The alternative has been changed to read as you suggested, "...associated with 'each' branch connection weld...". A total of four branch connections were selected. Two of the branch connections would fall under this relief request.