

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

MAY 25 1984

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Nos.: 50-352
50-353

Subject: Limerick Generating Station, Units 1 & 2
Additional Information for Materials
Engineering Branch (MTEB) Regarding
SER Confirmatory Issue #22 - Fracture
Toughness of Containment Pressure
Boundary

Reference: General Design Criteria (GDC) 51 Compliance
Audit for Limerick Units 1 and 2, conducted
on June 24, 1983.

Enclosure: "Acceptability of 24-Inch Class 1 Feedwater
Check Valves", Technical Report No.
1183-05EV, Revision 2, May 1984.

File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:

We are pleased to provide the enclosed report in order to address the concerns raised by J. Halapatz (NRC/MTEB) at the reference audit regarding the fracture toughness capability of the 24-inch class 1 feedwater check valves (1F074 A and B, 1F010 A and B, 2F074 A and B, 2F010 A and B).

The attached report provides documentation that these valves satisfy the acceptance criteria of GDC 51 ("Fracture Prevention of Containment Pressure Boundary") in the following three areas:

- (1) the check valve castings meet the material toughness requirements of the 1977 Summer Addenda of ASME Section III,
- (2) the permissible lowest service metal temperature was satisfactorily confirmed by available nil ductility transition temperature data, and

8405300498 840525
PDR ADOCK 05000352
PDR
E


Handwritten:
B
10/19
Boc
11

- (3) brittle fractures are highly unlikely as indicated by a fracture mechanics analysis.

In addition, the material of these valves was demonstrated to be satisfactory by Charpy impact testing and by in-situ metallographic examination of the Unit 1 valves as described in Appendix A of the attached report.

We trust that this information will assist you in the closeout of SER confirmatory issue #22.

Sincerely,



JHA/gra/050984950

cc: See Attached Service List

cc: Judge Lawrence Brenner	(w/o enclosure)
Judge Peter A. Morris	(w/o enclosure)
Judge Richard F. Cole	(w/o enclosure)
Troy B. Conner, Jr., Esq.	(w/o enclosure)
Ann P. Hodgdon, Esq.	(w/o enclosure)
Mr. Frank R. Romano	(w/o enclosure)
Mr. Robert L. Anthony	(w/o enclosure)
Maureen Mulligan	(w/o enclosure)
Charles W. Elliott, Esq.	(w/o enclosure)
Zori G. Ferkin, Esq.	(w/o enclosure)
Mr. Thomas Gerusky	(w/o enclosure)
Director, Penna. Emergency Management Agency	(w/o enclosure)
Angus Love, Esq.	(w/o enclosure)
David Wersan, Esq.	(w/o enclosure)
Robert J. Sugarman, Esq.	(w/o enclosure)
Martha W. Bush, Esq.	(w/o enclosure)
Spence W. Perry, Esq.	(w/o enclosure)
Jay M. Gutierrez, Esq.	(w/o enclosure)
Atomic Safety & Licensing Appeal Board	(w/o enclosure)
Atomic Safety & Licensing Board Panel	(w/o enclosure)
Docket & Service Section	(w/o enclosure)
James Wiggins	(w/o enclosure)
Timothy R. S. Campbell	(w/o enclosure)