



Carolina Power & Light Company

H. B. ROBINSON STEAM ELECTRIC PLANT
Post Office Box 790
Hartsville, South Carolina 29550

APR 27 1984

MAY 3 12:43

Robinson File No: 13510E

Serial: RSEP/84-269

Mr. James P. O'Reilly
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

H. B. ROBINSON STEAM ELECTRIC PLANT
DOCKET NO. 50-261
LICENSE NO. DPR-23
INSPECTION REPORT IER-83-024

Dear Mr. O'Reilly

Carolina Power and Light Company's November 3, 1984 response to the subject violation committed to revising procedures to functional test the safeguards test switch by March 31, 1984. The response also stated that, in the interim, work requests for testing these switches will contain a note to contact the I&C Foreman for post maintenance testing if the switch is replaced.

The interim action remains in effect. CP&L will schedule appropriate action on this item prior to startup. At present, a target date for procedure revision is August 3, 1984.

If you have any questions on this item, please contact me or my staff.

Very truly yours,

R. E. Morgan
General Manager
H. B. Robinson S. E. Plant

CLW/pls

8405300539 840509
PDR ADOCK 05000261
Q PDR