

Omaha Public Power District
1623 Harney Omaha, Nebraska 68102
402/536-4000

May 25, 1984
LIC-84-152

Mr. James R. Miller, Chief
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Division of Licensing
Operating Reactors Branch No. 3
Washington, D.C. 20555

Reference: (1) Docket No. 50-285
(2) Fort Calhoun Station Unit No. 1 Technical
Specification 3.3(2)e(i)

Dear Mr. Miller:


Steam Generator Tube Plugging

As required by Technical Specification 3.3(2)e(i), this letter reports the number of tubes plugged on the Fort Calhoun Station steam generators during the most recent inservice inspection conducted during the 1984 refueling and maintenance outage.

Five (5) tubes were plugged in steam generator RC-2A and five (5) were plugged in steam generator RC-2B. Specific details in regard to the steam generator tube plugging will be provided in the six (6) month report required by Technical Specification 3.3(2)e(ii).

It should be noted that this report does not include any plugging performed subsequent to the recent steam generator tube failure which was reported to the Commission in a letter dated May 22, 1984. The report for this plugging will be supplied separately.

Sincerely,



W. C. Jones
Division Manager
Production Operations

8405310007 840525
PDR ADOCK 05000285
Q PDR

WCJ/DJM:jmm

cc: LeBouf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N.W.
Washington, D.C. 20036

Mr. E. G. Tourigny, Project Manager
Mr. L. A. Yandell, Senior Resident
Inspector Employment with Equal Opportunity
Male/Female

A001
1/0