

April 3, 1992

Donald F. Schnoll  
Senior Vice President  
Nuclear

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Stop P1-137  
Washington, D.C. 20555

Gentlemen:

ULNRC-2608

DOCKET NUMBER 50-483  
CALLAWAY PLANT  
FACILITY OPERATING LICENSE NPF-30  
SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

A review of the Semi-Annual Effluent Release Reports (SERR) for the years 1987 through 1991 has revealed a problem with the way "burial" figures were reported. In 1987, Callaway Plant began shipping dry active waste to waste processors for volume reduction prior to burial. Volumes that were reported as "shipped" during that period were the actual volumes that left Callaway Plant with no volume reduction factored in. Table 3 for each of the SERR's between 1987 and 1991 have been updated and are attached to this letter.


Along with the above, this submittal includes an additional update to the July - December 1990 SERR and the July - December 1991 SERR. The July - December 1990 SERR reported an unmonitored release which resulted in a dose to the closest member of the public of  $7.5E-3$  mrem. While the release was identified in the SERR, the projected dose was not added to the total dose to the public due to normal operation. Therefore, Tables 1A, 1B, 5, 6 and 7 of the July - December 1990 SERR were updated and are attached to this letter.

Tables 1A, 1B, 5, 6 and 7 of the July - December 1991 SERR have been updated to reflect positive SR-90 sample analyses for the fourth quarterly composite samples which were unavailable from the contractor laboratory at the time of the SERR submittal. These updated tables are also attached to this submittal.

U.S. Nuclear Regulatory Commission  
April 3, 1992  
Page 2

If there are any questions relating to this  
information, please contact us.

Very truly yours,

A handwritten signature in dark ink, appearing to read "Donald F. Schnell". The signature is fluid and cursive, with the first name "Donald" being more prominent.

Donald F. Schnell

NGS/plh  
Enclosure

U.S. Nuclear Regulatory Commission  
April 3, 1992  
Page 3

cc: T. A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Dr. J. O. Cerch  
CFA, Inc.  
18225-A Flower Hill Way  
Gaithersburg, MD 20879-5334

R. C. Knop  
Chief, Reactor Project Branch 1  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Bruce Bartlett  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
RR#1  
Steedman, Missouri 65077

L. R. Wharton (2)  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
1 White Flint, North, Mail Stop 13E21  
11555 Rockville Pike  
Rockville, MD 20852

Manager, Electric Department  
Missouri Public Service Commission  
P.O. Box 360  
Jefferson City, MO 65102

William Kesler  
Regional Administrator  
Department of Natural Resources  
Central Regional Office  
P.O. Box 176  
Jefferson City, MO 65102