



Entergy Operations

Entergy Operations, Inc.

Route 3 Box 137G
Russellville, AR 72801
Tel: 501-964-8888

Neil S. "Buzz" Carns

Vice President
Operations ANO

October 11, 1991

2CAN109109

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NYP-6
Gaseous Activity for Purge and Exhaust Isolation
Revised Technical Specification Change Request

Gentlemen:

On February 20, 1991, Entergy Operations requested a change (2CAN029103) to the ANO-2 Technical Specifications revising Table 3.3-6 and 4.3-3 to require the process monitor for gaseous activity for purge and exhaust isolation be operable when the monitor is actually in use rather than during all Modes.

Based on a conversation with the ANO-2 NRR Project Manager, Entergy Operations is submitting a proposed revision to the previous request. The revision changes our proposed Applicability from "During purge or when ventilating during Mode 6 Core Alterations" to "Modes 5 and 6". Additionally, Action 16, which currently reads "With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirements, comply with the ACTION requirements of Specification 3.9.9" is to be replaced. Specification 3.9.9 requires suspension of all operations involving movement of fuel assemblies or CEAs within the pressure vessel. The proposed Action 16 requires securing the purge system during fuel movement and containment purge operations and provides ACTIONS for continuous ventilation with an inoperable monitor.


Additionally, a change is being made to the Bases for this Specification to distinguish between a purge and continuous ventilation and to provide clarification of required actions. As this involves no intent change to our previous submittal, the no significant hazards consideration from our previous submittal is still applicable.

9110250076 911011
PDR ADOCK 05000368
P PDR

Handwritten: 1001

Should you or your staff have questions regarding this request, please do not hesitate to call.

Very truly yours,



NSC/JJF/lpi
Attachments

cc: Mr. Robert Martin
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. Thomas W. Alexion
NRR Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 11-D-23
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Ms. Sheri Peterson
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 11-D-23
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Ms. Greta Dicus, Director
Division of Radiation Control
and Emergency Management
Arkansas Department of Health
4815 West Markham Street
Little Rock, AR 72201

STATE OF ARKANSAS)
)
COUNTY OF LOGAN)


SS

OATH

I, N. S. Carns, being duly sworn, subscribe to and say that I am Vice President, Operations AND for Entergy Operations, Inc.; that I have full authority to execute this oath; that I have read the document numbered 2CAN109109 and know the contents thereof; and that to the best of my knowledge, information and belief, the statements in it are true.


N. S. Carns

SUBSCRIBED AND SWORN TO before me, a Notary Public in and for the County and State above named, this 11th day of October, 1991.


Notary Public

My Commission Expires:
May 11, 2000