

STONE AND WEBSTER MICHIGAN, INC.  
P.O. BOX 1963, MIDLAND, MICHIGAN 48640

PRINCIPAL STAFF			
RA	RA	DPRP	Aug 13
D/RA		DE	
A/RA		DRMSP	
RC		DRMA	
PAO		SCS	
SGA		ML	
ENF		File	ha

50-329  
50-330

DATE	5/23/84
J. O. NO.	14509
P. O. NO.	
LTR. NO.	SWM-126
REF.	

DEAR SIRs:

THE FOLLOWING ARE ☒ ATTACHED ☐ SENT SEPARATELY:

<input checked="" type="checkbox"/> COPIES	<input type="checkbox"/> PRINTS	<input type="checkbox"/> REPRODUCIBLES	<input type="checkbox"/> MICROFILM APERTURE CARDS
EACH OF			
<input type="checkbox"/> DRAWINGS	<input type="checkbox"/> SPECIFICATIONS		
<input checked="" type="checkbox"/> DOCUMENTS	<input type="checkbox"/> NOTES OF CONFERENCE		

STATUS		PLEASE NOTE	SENT FOR YOUR
<input type="checkbox"/> FINAL	<input checked="" type="checkbox"/> APPROVED	<input type="checkbox"/> REVISIONS	<input type="checkbox"/> APPROVAL
<input type="checkbox"/> PRELIMINARY	<input type="checkbox"/> APPROVED AS REVISED	<input type="checkbox"/> OMISSIONS	<input type="checkbox"/> COMMENT
<input type="checkbox"/> NO COMMENT	<input type="checkbox"/> UNACCEPTABLE	<input type="checkbox"/> ADDITIONS	<input type="checkbox"/> USE
<input type="checkbox"/> SUGGESTIONS AS NOTED	<input checked="" type="checkbox"/> CLOSED	<input type="checkbox"/> CORRECTIONS	<input checked="" type="checkbox"/> FILES
		<input type="checkbox"/> COMMENTS	<input type="checkbox"/> CONCURRENCE

YOUR ATTENTION IS DIRECTED TO THE FOLLOWING:

RELEASED FOR: ☐ FABRICATION ☐ PURCHASE OF NECESSARY MATERIALS

☐ PLEASE REVISE AND SUBMIT \_\_\_\_\_ PRINTS \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ MICROFILM APERTURE CARDS

☐ PLEASE SUBMIT \_\_\_\_\_ PRINTS \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ MICROFILM APERTURE CARDS OF ☐ DOCUMENTS ☐ DRAWINGS ☐ SHOP DETAIL

☐ PLEASE RETURN ONE COPY EACH OF THIS MATERIAL BEARING YOUR APPROVAL OR COMMENTS

☐ PLEASE ACKNOWLEDGE RECEIPT OF THIS MATERIAL BY SIGNING AND RETURNING THE ENCLOSED COPY OF THIS FORM

☐ WE TRUST THAT THESE NOTES ARE IN ACCORDANCE WITH YOUR UNDERSTANDING. IF NOT, PLEASE ADVISE US

IMPORTANT SHOULD ANY REVISION TO DOCUMENTS OR DRAWINGS RETURNED HEREWITH INVOLVE A PRICE INCREASE THE SUPPLIER MUST NOTIFY STONE & WEBSTER PURCHASING DEPARTMENT WITHIN TEN (10) DAYS EVEN THOUGH A DEFINITE ESTIMATE CANNOT BE GIVEN AT THE TIME OTHERWISE THE PURCHASER WILL CONSIDER THE REVISIONS MADE WITHOUT COST.

The following Closed CIO Item/Hold Point Notification(s) is (are) attached for your action/information:

ITEM 063

DISTRIBUTION:

Job File C.3 (orig + 1)  
DLQuamme, CPCo  
NIRichel, CPCo  
RAWells, CPCo  
JGKeppler, NRC  
JHarrison, NRC  
BLBurgess, NRC (site)  
APAmoruso (2)  
KRArndt/Chrono/Vault w/o attach(2)  
Initiator

J. E. Karr  
CIO Program Manager

8406010272 840523  
PDR ADOCK 05000329  
S PDR

TE01 11  
MAY 29 1984

Chase  
Kishner  
3-15-84

**STONE & WEBSTER**  
**CONSTRUCTION IMPLEMENTATION**  
**OVERVIEW**  
**MIDLAND NUCLEAR PLANT J.O. NO. 14509**

ITEM NUMBER 063 HOLD POINT NUMBER

- ☒ TRACKED ACTION ITEM  
☐ TRACKED INFORMATION ITEM  
☐ TRACKED RECOMMENDATION ITEM  
☐ UNTRACKED ITEM  
☐ HOLD POINT NOTIFICATION

REFERENCE(S) STATUS ASSESSMENT  
FPD 3.000 REV. 11 SECTION 8.0

**CONDITION DETAILS**

Status Assessment was being performed in Module 120D on March 13, 1984 using FSK prints that were not marked "Status Assessment Print" or with an expiration date. These prints were being used as referenced prints, and stamped "Uncontrolled not to be used for Construction."

See Attachment 1 for specific drawings and revisions.

NOTE: 3 drawings in use were of a later revision than available at Document Control  
2 drawings in use were out of date. The above condition was observed during a review of six reference drawings being used for status assessment.

☒ YES (PAGE NO.'S) 1 ☐ NO

**ATTACHMENTS**

DATE RESPONSE REQ'D. 3/21/84 INITIATOR DATE 3/15/84 INITIATION APPROVED/DATE 3-15-84

**RESPONSE**

Attachment 2 provides the final response addressing your concerns delineated in Tracked Action Item 063.

\*CIO has reviewed CPCo's response to this item (i.e., Attachment 2 - provided under cover of CPCo Transmittal No. CSC-7772, dated 5-21-84) and considers it satisfactory, thereby closing CIO Item 063.

☒ YES (PAGE NO.'S) 2 ☐ NO

**ATTACHMENTS**

EST. CORRECTIVE ACTION COMPLETION DATE N/A. RESPONDENT [Signature] TITLE Const. Spt DATE 5/21/84

RESPONSE ACCEPTED\* Richard Scollan DATE 5-23-84 RESPONSE VERIFIED/CLOSED [Signature] DATE 5-23-84

\*NOTE: The ORIGINAL document was not returned with CPCo's response; i.e., this copy now serves as the original.

DRAWING NUMBER

FSK JO 57  
FSK JO 63 SH.1  
FSK JO 66  
FSK JO 67 SH.1  
FSK JO 72 SH.1

REVISION INFIELD

Rev. 6  
Rev. 9  
Rev. 10  
Rev. 7  
Rev. 6

REVISION IN DOCUMENT CONTROL

Rev. 5  
Rev. 10  
Rev. 9  
Rev. 8  
Rev. 5

The following is the final response to address your concerns delineated in your Tracked Action Item 063.

- I. As was reported in Tracked Action Item 063, three drawings (FSK JO 57, FSK JO 66, and FSK JO 72 sheet 1) in use as reference documents were of a later revision than available at Document Control. These three drawings were obtained from the Instrumentation Design Group prior to distribution by Document Control. Also, as was reported in Tracked Action Item 063, two drawings (FSK JO 63 sheet 1 and FSK JO 67 sheet 1) in use as referenced prints were out of date compared to the latest revision at Document Control. The two old revisions were being utilized as a reference document to determine if the items had been redesigned after installation and for the determination if an FCR, NCR or Punchlist Rework Entry was required. These reference documents were stamped "Uncontrolled not to be used for Construction."

A reverification using the current revisions has been completed on instrument installation #FSK-JB2-0045 which was previously status assessed using the five reference prints of incorrect drawing revisions, as was identified on the subject Tracked Action Item 063. The reverification revealed that no nonconforming conditions were missed when the system was status assessed using the incorrect reference drawing revisions.

It has been determined that this was an isolated case and that engineering personnel understand the requirements, based on the overviews performed by the status assessment "Self Appraisal Team" (SAT).

- II. To preclude recurrence of this situation, field engineering issued an administrative instruction #0-7487 on the use of Status Assessment Prints (SAP's) and associated reference documents. The use of status assessment prints and associated reference documents provides a solid field engineering base of system status during Phase 1 of the CCP.
- III. Field Engineering has developed Field Procedure FPG-9.990 to clarify and provide direction for the use of Status Assessment Prints (SAP's) and associated reference documents. This procedure was issued on May 21, 1984 and supersedes the Field Engineering Administrative Instruction #0-7487.

Training requirements for FPG-9.990 have been added to Field Procedure FPG-2.000 "Construction Training Program". Training will be completed and documented in accordance with the requirements of FPG-2.000.

In addition, the use of Field Engineering Administrative Instructions has been discontinued. All future changes, clarifications and interpretations of Field Procedures will be in accordance with FPG-1.000.

- IV. A system of check and balance is provided in the requirements of the CCP to assure that all installations are completed to the latest engineering criteria.

Prior to commencement of physical work in Phase II of the CCP, the latest criteria is again verified against the status assessment prints to determine if additional design changes have been made.

Additionally, during Phase II of CCP, the final installed system will be inspected by MPQAD-QC for acceptability to the latest design criteria.

If you have any questions, please contact Don Horn at extension 7704.