



Tennessee Valley Authority, Post Office Box 2066, Safety County, Tennessee 37393

Jack L. Wilson
Vice President, Sequoyah Nuclear Plant

November 27, 1991

TVA-SQN-TS-91-16

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)	Docket Nos. 50-327
Tennessee Valley Authority)	50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION (TS) CHANGE 91-16,
"REVISION OF ACTIONS FOR TS TABLE 3.3-3"

In accordance with 10 CFR 50.90, we are enclosing a requested amendment to Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The proposed change revises the required actions for the functions under Item 7, "Loss of Power," of Table 3.3-3 to support TS-required surveillance testing.


The proposed TS change is identified in Enclosure 1. The justification for the proposed TS change is provided in Enclosure 2. A proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92 is provided in Enclosure 3.

Handwritten signature/initials: ADOCK


U.S. Nuclear Regulatory Commission
November 27, 1991

Please direct questions concerning this issue to K. C. Weller at
(615) 843-7527.

Sincerely,


J. L. Wilson

Sworn to and subscribed before me
this 27th day of NOVEMBER 1991


Notary Public
My Commission Expires 8-4-92

Enclosures

cc (Enclosures):

American Nuclear Insurers
Attention: Librarian
The Exchange, Suite 245
270 Farmington Avenue
Farmington, Connecticut 06032

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. Michael H. Mobley, Director (w/o Enclosures)
Division of Radiological Health
T.E.R.R.A. Building
150 9th Avenue, N
Nashville, Tennessee 37203

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323