

SHANSTROM NUCLEAR ASSOCIATES

P. O. BOX 1122

DARIEN, CONNECTICUT 06820

(203) 655-9400

May 24, 1984

Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation  
USNRC  
Washington, DC 20555

Dear Mr. Eisenhut:


A 10CFR21 notification has been submitted to the Office of Inspection and Enforcement regarding a bug in a computer code which affects calculation of technical specification parameters for the nuclear enthalpy rise peaking factor.

Enclosed is a copy of this notification for your information.

The bug has been corrected and no violation of technical specification parameters occurred.

I have been in touch with Richard Lobel, Marv Dunenfeld, and Dan Fieno in the Core Performance Branch of the Division of Systems Integration. A separate copy of the notification has been sent to Richard Lobel.

Very truly yours,

  
Raymond I. Shanstrom

cc: Mr. Richard Lobel

Enclosure