

IE22
1/1



ARKANSAS POWER & LIGHT COMPANY

POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

May 25, 1984

2CANØ58412

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Licensee Event Report
No. 82-038/03X-1

Gentlemen:

In accordance with Arkansas Nuclear One - Unit 2 Technical Specification 6.9.1.9.b, attached is the subject report concerning incorrect wiring of Emergency Feedwater control valve 2CV-1076-2. This is a revision to a previous submittal dated December 6, 1982.

Very truly yours,

John R. Marshall
Manager, Licensing

JRM:RJS:ac

Attachment

cc: Mr. Richard P. Denise, Director
Division of Resident Reactor Projects
and Engineering Programs
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

IE 22
1/1