

Omaha Public Power District  
444 South 16th Street Mall  
Omaha, Nebraska 68102-2247  
402/636-2000

June 26, 1995  
LIC-95-0112

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Reference: Docket No. 50-285

SUBJECT: Application for Amendment of Operating License

Enclosed please find Omaha Public Power District's (OPPD) "Application for Amendment of Operating License" which seeks to amend Technical Specification 2.3 extending the allowed outage time (AOT) from 24 hours to seven (7) days for an inoperable low pressure safety injection pump. This amendment request is a collaborative effort of participating Combustion Engineering Owners Group members based on an integrated assessment of plant operations and deterministic and probabilistic analyses.

Attachment A contains a markup reflecting the requested changes of the Technical Specifications. Attachment B provides the "Discussion, Justification and No Significant Hazards Consideration." Attachment C contains a copy of Combustion Engineering Report CE NPSD-995, titled "Joint Applications Report for Low Pressure Safety Injection System AOT Extension," dated May 1995.


100001

A001  
1/37

U. S. Nuclear Regulatory Commission  
LIC-95-0112  
Page 2

If you have additional questions, or require further information, please do not hesitate to contact me or members of my staff.

Sincerely,



W. G. Gates  
Vice President

WGG/mle

Attachments

c: Winston & Strawn  
L. J. Callan, NRC Regional Administrator, Region IV  
T. Y. Liu, NRC Acting Project Manager  
W. C. Walker, NRC Senior Resident Inspector  
P. J. Hijeck, CEOG Assistant Project Manager  
B. E. Casari, Director, Environmental Health Division,  
State of Nebraska, Department of Health

