

START NO. 1-90-148

XLS 95 JUL 27 P4:10
4/24/90

Sheet 1 of 1

COMPLETION SHEET 1

TO: DIESEL GENERATOR SYSTEM ENGINEER
FROM: UNIT SHIFT SUPERVISOR (UNIT 1)

WORKING COPY

4-24-90

Diesel Generator Tested: ☒ DG1A ☐ DG1B

Start Date: 3/30/90

Shutdown Date: 3/30/90

Start Time: 1920

Shutdown Time: 2115

Start Engine Hours: 725.3

Shutdown Engine Hours: 727.1

Start preceded by turbocharger prelubrication: ☒ Yes ☐ No

Reason for start:

☒ Maintenance Troubleshooting☐ Functional Testing☐ SI ☐ Blackout ☐ Other:

Reason for trip or failure to start: NA

☐ Manual ☐ Equipment failure ☐ Trip signal ☐ Alarm Response☐ Other:

DR# (if known)

WRT # (If Known)

List any conditions that would have resulted in Diesel Generator failure to start:

NA

Comments: Testing start and stop circuitry

Emerg. Start to do
Bubble Test

Diesel Generator Start Evaluation:

☒ Successful Start☐ Valid Test☐ Valid Failure☒ Non-Valid Test☐ Non-Valid Failure

Completed By: J. C. [Signature]

4-24-90

0150

Date

Time

Reviewed By: J. C. [Signature]
Unit Shift Supervisor

4-24-90

0150

Date

Time

Copy sent to
Diesel Generator System Engineer9508110236 950711
PDR ADOCK 05000424
G PDR

Shift Clerk

Date

Unit Shift Supervisor

Date