

James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342-3840



Radford J. Converse
Resident Manager

January 13, 1992
JAFP 92-0031

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Attention: Document Control Desk

SUBJECT: OPERATING STATUS REPORT

Reference: DOCKET NO. 50-333

Dear Sir:

Enclosed please find the James A. FitzPatrick Nuclear Power Plant Operating Status Report for the month of December 1991.

If there are any questions concerning this report, please contact Russell Flagg at (315) 349-6590.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'R. Converse'.

RADFORD J. CONVERSE

RJC:RGF:ls
Enclosures

CC: JAF Department Heads
White Plains Office
TS File
DCC

IE24
11

**NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

DOCKET NO.: 52-333
UNIT NAME: FITZPATRICK
DATE: JANUARY 1991
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

OPERATING STATUS

1. Unit Name: FITZPATRICK
2. Reporting Period: 911201 - 911231
3. Licensed Thermal Power (MWe): 3410
4. Nameplate Rating (Gross MWe): 3410
5. Design Electrical Rating (MVA): 3410
6. Maximum Dependable Capacity (MWe): 3410
7. Maximum Dependable Capacity (MVA): 3410

NOTES:

8. If changes occur in capacity ratings (Items 6 & 7) since last report, give reasons:

9. Power level to which restricted, if any (Net MWE):

10. Reasons for restrictions, if any:

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period:	744.0	8760.0	144026.0
12. Number of Hours Reactor was Critical:	0	4675.2	104831.4
13. Reactor Reserve Shutdown Hours:	0	0	0
14. Hours Generator On-Line:	0	4536.7	101731.2
15. Unit Reserve Shutdown Hours:	0	0	0
16. Gross Thermal Energy Generated (MWH):	0	10389560.0	223974910.0
17. Gross Electrical Energy Generated (MWH):	0	3501640.0	76322860.0
18. Net Electrical Energy Generated (MWH):	0	3376750.0	73269365.0
19. Unit Service Factor:	0	51.8	70.6
20. Unit Availability Factor:	0	51.8	70.6
21. Unit Capacity Factor (using MDC Net):	0	49.4	65.6
22. Unit Capacity Factor (using DER Net):	0	47.2	62.3
23. Unit Forced Outage Rate:	100.0	46.8	12.8

24. Shutdowns scheduled over next 6 months (type, date, and duration of each):
Refuel outage scheduled to commence January 11, 1992 lasting approximately 95 days.

5. If shutdown at end of report period, estimated date of startup: April 15, 1992

26. Units in Test Status (prior to commercial operation):
- | | FORECAST | ACHIEVED |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
AVERAGE DAILY UNIT POWER LEVEL

REPORT MONTH: DECEMBER 1991

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: JANUARY 1991
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	0
16	0		

SUMMARY: The FitzPatrick Plant remained shutdown for the entire reporting period.

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
UNIT SHUTDOWNS REPORT

REPORT MONTH: DECEMBER 1991

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: JANUARY 1991
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

NO.	DATE	TYPE	D U H R O A U T R I S T I O N	R E A S O N	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT	S Y C S O T D E E M	C O M C P O D N E N T	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
9	911201	F	744	B	1	N/A	N/A	N/A	S/L for preparations for refueling and Appendix R inspections (cumulative hours 814.5).

1
F: FORCED
S: SCHEDULED

2
REASON:
A. EQUIPMENT FAILURE (EXPLAIN)
B. MAINTENANCE OR TEST
C. REFUELING
D. REGULATORY RESTRICTION
E. OPERATOR TRAINING AND LICENSE EXAMINATION
F. ADMINISTRATIVE
G. OPERATIONAL ERROR (EXPLAIN)
H. OTHER (EXPLAIN)

3
METHOD:
1. MANUAL
2. MANUAL SCRAM
3. AUTOMATIC SCRAM
4. CONTINUED
5. REDUCED LOAD
9. OTHER

4
EXHIBIT G - INSTRUCTIONS
FOR PREPARATION OF DATA ENTRY
SHEETS FOR LICENSEE EVENT
REPORT (LER) FILE (NUREG-0161)

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

REPORT MONTH: DECEMBER 1991

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: JANUARY 1991
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

The FitzPatrick Plant remained shutdown for this entire reporting period.

The major maintenance activities were limited to work on systems required to support the upcoming Refueling Outage.