



PECO ENERGY

Robert W. Boyce
Plant Manager
Limerick Generating Station

PECO Energy Company
Limerick Generating Station
PO Box 2300
Sanatoga, PA 19464-0920
215 327 1200 Ext. 2000

10CFR 50.73

August 18, 1995
Docket Nos. 50-352
50-353
License Nos. NPF-39
NPF-85

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Licensee Event Report
Limerick Generating Station - Units 1 and 2

This LER reports actuations of the Unit 1 and Unit 2 Primary Containment and Reactor Vessel Isolation Control Systems, Engineered Safe Features, resulting from the inadvertent grounding of an electrical lead during replacement of a keyswitch. The cause was due to unclear management expectations surrounding work activities having the potential of creating a ground or short circuit condition.

Reference:	Docket Nos. 50-352 50-353
Report Number:	2-95-007
Revision Number:	00
Event Date:	July 20, 1995
Report Date:	August 18, 1995
Facility:	Limerick Generating Station P.O. Box 2300, Sanatoga, PA 19464-2300

This LER is being submitted pursuant to the requirements of 10CFR50.73(a)(2)(iv).

Very truly yours,

Robert W. Boyce
DMS:cah

cc: T. T. Martin, Administrator Region I, USNRC
N. S. Perry, USNRC Senior Resident Inspector, LGS

050022

9508250377 950818
PDR ADDCK 05000353
S PDR

IF22
1/1