



Northern States Power Company

Monticello Nuclear Generating Plant
2807 West Hwy 75
Monticello, Minnesota 55362-9637

August 18, 1995

U S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

10 CFR Part 50
Section 50.90

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Revision 2 to License Amendment Request Dated June 8, 1994
Standby Gas Treatment and Secondary Containment Technical Specifications (TACM89739)

In our License Amendment Request dated June 8, 1994, Monticello proposed changes to section 3.7/4.7, Standby Gas Treatment System, concerning the surveillance requirement to operate the Standby Gas Treatment System monthly as well as revised performance requirements for the Standby Gas Treatment System filters and process stream inline electric heaters. The proposed amendment included revised Standby Gas Treatment System and Secondary Containment limiting conditions for operation specified in section 3.7 to establish consistency. Changes were also proposed for the Secondary Containment capability surveillance requirement specified in section 4.7.

In our License Amendment Request Dated June 8, 1994, Monticello proposed a change to section 4.7.C.1 to add the following provision after the requirement for demonstrating secondary containment capability under calm wind conditions:

If calm wind condition do not exist during this testing, the test data is to be corrected to calm wind conditions.

In our April 20, 1995 submittal with subject, Revision 1 to License Amendment Request Dated June 8, 1994, Monticello added a reference in the Technical Specification Bases to provide additional information concerning the means employed to correct secondary containment capability test data to calm wind conditions.

By telephone conference call held June 16, 1995 between members of the NRC Staff and Monticello Plant staff, additional information was requested concerning the means employed to correct secondary containment capability test data to calm wind conditions. This submittal provides the requested information. In addition, the Staff requested that reference to the information contained in this submittal be provided in the Technical Specification Bases.

Exhibit A contains a description of the means employed to correct secondary containment capability test data to calm wind conditions. Exhibit B contains the current Technical Specification Bases page 188 marked up with the proposed changes. Exhibit C contains

9508280103 950818
PDR ADDCK 05000263
P PDR

ADD. 1

USNRC
August 18, 1995
Page 2


Northern States Power Company

revised Monticello Technical Specification Bases page 188. This revised page supersedes the proposed changes submitted for page 188 in our correspondence dated April 20, 1995. This submittal does not impact the evaluations performed on this subject in Exhibit A of our previous submittals.

This submittal contains the following new NRC commitment:

The general methodology described in Exhibit A will be employed to correct Secondary Containment capability tests to calm wind conditions.

Please contact Marvin Engen, Sr Licensing Engineer, (612-295-1291) if you require further information related to this request.



William J Hill
Plant Manager
Monticello Nuclear Generating Plant

c: Regional Administrator-III, NRC
NRR Project Manager, NRC
Resident Inspector, NRC
State of Minnesota
Attn: Kris Sanda

Attachments: Affidavit to the US Nuclear Regulatory Commission
Exhibit A - Additional Information Concerning License Amendment Request
Dated June 8, 1994, Standby Gas Treatment and Secondary
Containment Technical Specifications
Exhibit B - Technical Specification Bases Page marked up with proposed
change
Exhibit C - Revised Monticello Technical Specification Bases Page

TRANSMITTAL MANIFEST

NORTHERN STATES POWER COMPANY

NUCLEAR LICENSING DEPARTMENT

MONTICELLO NUCLEAR GENERATING PLANT

Revision 2 to License Amendment Request Dated June 8, 1994
Standby Gas Treatment and Secondary Containment Technical Specifications (TACM89739)

Manifest Date: August 18, 1995

Correspondence Date: August 18, 1995

Monticello Internal Site Distribution Special Instructions

Kaleen Hilsenhoff.....USAR File.....Yes___ No_x_
Steve LuddersNRC Commitment.....Yes_x_ No___
Lila Imholte.....Monti OC Sec.....Yes___ No_x_ - 11, No dist to OC members below if YES
Mel Opstad.....Monti SAC Sec.....Yes_x_ No___ - 5
*Mail Room.....Monti Posting.....Yes___ No_x_ - 7

Monticello Internal Site Distribution:

*Monti Document Control File	J C Grubb, NGSS, OC
W J Hill, Plant MGR, SAC, OC	L L Nolan, GSSA, OC
C A Schibonski, GSE, OC	B D Day, MGR MTC, OC
M F Hammer, GSM, OC	Operating Experience Coord
J E Windschill, GSRS, OC	W A Shamlu, NQD
M W Onnen, GSO, OC	Monti Site Lic File
Dave Scott	NRC Resident Inspector's Office
Steve Hammer	
Lic History File	

NSP Internal Distribution

E L Watzl	R O Anderson, Dir LMI, SAC
Mike Wadley, PI	T E Amundson, Dir NQD, SAC
	Communications Dept Yes___ No_x__

External NSP Distribution

*Doc Control Desk, NRC	Kris Sanda, State of Minn
Regional Admin-III, NRC	J E Silberg
T J Kim, NRR-PM, NRC	

* Advance Distribution made by Site Licensing