


# VERMONT YANKEE NUCLEAR POWER CORPORATION



P.O. Box 157, Governor Hunt Road  
Vernon, Vermont 05354-0157  
(802) 257-7711

August 24, 1995  
BVY 95-94

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

REFERENCE: Operating License DPR-28  
Docket No. 50-271  
Reportable Occurrence No. LER 95-14

Dear Sirs:

As defined by 10 CFR 50.73, we are reporting the attached Reportable Occurrence as LER 95-14.

Very truly yours,

VERMONT YANKEE NUCLEAR POWER CORPORATION

  
for Robert J. Wanczyk  
Plant Manager

cc: Regional Administrator  
USNRC  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

7508280273 950824  
PDR ADOCK 05000271  
S PDR

JE281

NRC Form 366 (4-95)				U.S. NUCLEAR REGULATORY COMMISSION				APPROVED BY OMB NO. 3150-0104 EXPIRES 04/30/98 ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS MANDATORY INFORMATION COLLECTION REQUEST: 50.0 HRS. REPORTED LESSONS LEARNED ARE INCORPORATED INTO THE LICENSING PROCESS AND FED BACK TO INDUSTRY. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE INFORMATION AND RECORDS MANAGEMENT BRANCH (T-6 F33), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555-0001, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.			
<b>LICENSEE EVENT REPORT (LER)</b>											
<b>FACILITY NAME (1)</b> VERMONT YANKEE NUCLEAR POWER STATION						<b>DOCKET NUMBER (2)</b> 05000271		<b>PAGE (3)</b> 01 OF 05			
<b>TITLE (4)</b> INCOMPLETE IMPLEMENTATION OF 10CFR50 APPENDIX "R" BASED ON IDENTIFIED DEFICIENCIES IN THE SAFE SHUTDOWN CAPABILITY ANALYSIS											
<b>EVENT DATE (5)</b>			<b>LER NUMBER (6)</b>			<b>REPORT DATE (7)</b>			<b>OTHER FACILITIES INVOLVED (8)</b>		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAME	DOCKET NO.(S)	
07	25	95	95	-- 014 --	00	08	24	95	N/A	05000	
<b>OPERATING MODE (9)</b>		N		<b>THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: CHECK ONE OR MORE (11)</b>							
				20.2201(b)		20.2203(a)(2)(v)		50.73(a)(2)(i)		50.73(a)(2)(viii)	
<b>POWER LEVEL (10)</b>		94%		20.2203(a)(1)		20.2203(a)(3)(i)		X 50.73(a)(2)(ii)		50.73(a)(2)(x)	
				20.2203(a)(2)(i)		20.2203(a)(3)(ii)		50.73(a)(2)(iii)		73.71	
				20.2203(a)(2)(ii)		20.2203(a)(4)		50.73(a)(2)(iv)		OTHER	
				20.2203(a)(2)(iii)		50.36(c)(1)		50.73(a)(2)(v)		(Specify in Abstract below or in NRC Form 366A)	
				20.2203(a)(2)(iv)		50.36(c)(2)		50.73(a)(2)(vii)			
<b>LICENSEE CONTACT FOR THIS LER (12)</b>											
<b>NAME</b> ROBERT J. WANCZYK, PLANT MANAGER								<b>TELEPHONE NO. (Include Area Code)</b> 802-257-7711			
<b>COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)</b>											
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	.....	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	
					.....						
					.....						
					.....						
					.....						
<b>SUPPLEMENTAL REPORT EXPECTED (14)</b>								<b>EXPECTED SUBMISSION DATE (15)</b>		MO DAY YEAR 10 31 95	
X	YES (If yes, complete EXPECTED SUBMISSION DATE)				NO						

**ABSTRACT** (Limit to 1400 spaces, i.e., approximately 15 single-spaced typewritten lines) (16)

On 07/25/95, at 1410 hours, an ongoing review of documents and correspondence associated with 10CFR50 Appendix "R" determined that the "hot short" concern described in NRC Information Notice 92-18 was applicable to Vermont Yankee such that the operation of various Motor Operated Valves, from Alternate Shutdown Panels, could be impacted in the event of a fire in one of four plant areas. Specifically, the issue involves the potential impact of a fire on plant equipment relied upon in the Vermont Yankee Safe Shutdown Capability Analysis for placing and maintaining the reactor in "cold shutdown." Subsequent to this discovery, additional Appendix "R" vulnerabilities were identified such that under certain fire scenarios, loss of RCIC function in the Alternate Shutdown mode, or inadvertent primary system depressurization could result from fire damage to RCIC or SRV cabling. The root cause(s) of these events will be thoroughly investigated by an independent, multi-disciplined task team.

Corrective actions for these events include the establishment of compensatory measures (firewatches) in the affected areas, and the formation of multiple task teams to investigate and resolve the identified issues. Full compliance with Appendix "R" requirements, without the need for crediting the compensatory measures detailed in this report, will be achieved by no later than the end of the 1996 Refueling Outage.

A supplement to this LER will be submitted to document the findings of the Root Cause Analysis task team. Based on task team investigations, additional corrective actions will be detailed in the LER supplement, as required.

NRC Form 366 U.S. NUCLEAR REGULATORY COMMISSION (4-95)		APPROVED BY OMB NO. 3150-0104 EXPIRES 04/30/98 ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS MANDATORY INFORMATION COLLECTION REQUEST: 50.0 HRS. REPORTED LESSONS LEARNED ARE INCORPORATED INTO THE LICENSING PROCESS AND FED BACK TO INDUSTRY. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE INFORMATION AND RECORDS MANAGEMENT BRANCH (T-6 F33), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555-0001, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.	
LICENSEE EVENT REPORT (LER)			
FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)	
		YEAR	SEQUENTIAL NUMBER
VERMONT YANKEE NUCLEAR POWER CORPORATION	05000271	95	-- 014 -- 00
			REV #
			C2 OF 05

TEXT (If more space is required, use additional copies of NRC Form 366A) (17)

## DESCRIPTION OF EVENT

On 07/25/95, at 1410 hours, with the reactor at 94% of rated power, an ongoing review of documents and correspondence associated with 10CFR50 Appendix "R" determined that the "hot short" concern described in NRC Information Notice 92-18 was applicable to Vermont Yankee such that the operation of various Motor Operated Valves (MOVs) from Alternate Shutdown Panels could be impacted in the event of a fire in certain plant areas. Specifically, the issue involves the potential impact of a fire in the Control Room, Cable Vault, or Reactor Building Fire Zones RB-1 or RB-3, on plant equipment relied upon in the Vermont Yankee Safe Shutdown Capability Analysis (SSCA) for placing and maintaining the reactor in "cold shutdown." This condition potentially renders the plant outside design basis in that it is not enveloped by the present Appendix "R" analysis. Based on this discovery, the Resident NRC Inspectors were briefed, and compensatory measures (fire watches) were promptly put into place such that the intent of 10CFR50 Appendix "R" was satisfied. In addition, copies of the associated Event Report and NRC Information Notice 92-18 were placed in the Operations Night Order Log Book for heightened operator awareness of the issue.

On 07/26/95, the subject "hot short" Event Report was reviewed at length by the Plant Operations Review Committee (PORC). Topics of discussion included: 1) the need to review actions contained within the related operating procedures, 2) the questioning of the potential for Safety Relief Valve (SRV)(EIIS = SB) cable vulnerability, and 3) the recommendation to develop a task force to pursue resolution of this issue. Based on the PORC meeting, an Operations Standing Order was issued to establish formal guidance on the implementation of additional fire prevention controls in the susceptible areas, and convey management's intent to have operators initiate a reactor SCRAM and bring the plant to "cold shutdown" in the event of a confirmed fire that affects plant equipment in the Control Room, Cable Vault, or in Reactor Building Fire Zones RB-1 or RB-3. These compensatory measures were discussed at the 07/27/95 plant management morning meeting for increased awareness of the current Appendix "R" issues.

On 07/27/95, a followup to one of the questions raised by PORC during their review of the "hot short" concern identified a deficiency in the SSCA relative to the specific response to a fire in Reactor Building Zone RB-3. The analysis credits use of the Reactor Core Isolation Cooling (RCIC) system (EIIS = BN) in the Alternate Shutdown mode, and repair of a cable for manual operation of a Safety Relief Valve. However, it was determined that additional wire and terminations for the SRV could be damaged for a fire in this area, making repair of the circuit unachievable. As a result, on 07/28/95, at 0000 hours, with the reactor at 100% of rated power, an event report for this issue was submitted, and compensatory measures were taken to satisfy the intent of Appendix "R" requirements.

On 07/28/95, Vermont Yankee management announced the formation of three task force teams to investigate the recently identified Appendix "R" issues. At the 07/31/95 plant management morning meeting, the function and scope of review of these (Hot Short, Repair, and Self Assessment) teams were outlined. Subsequently, investigations by the task teams identified additional Appendix "R" vulnerabilities in the same plant fire zone areas. Specifically, under certain fire scenarios, loss of RCIC function in the Alternate Shutdown mode or inadvertent primary system depressurization could result from fire damage to RCIC or SRV cabling. Based on this, the existing compensatory (fire watch) measures were readjusted to account for the additional findings.

NRC Form 366 U.S. NUCLEAR REGULATORY COMMISSION (4-95)		APPROVED BY OMB NO. 3150-0104 EXPIRES 04/30/98 ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS MANDATORY INFORMATION COLLECTION REQUEST: 50.0 HRS. REPORTED LESSONS LEARNED ARE INCORPORATED INTO THE LICENSING PROCESS AND FED BACK TO INDUSTRY. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE INFORMATION AND RECORDS MANAGEMENT BRANCH (T-6 F33), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555-0001, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.			
LICENSEE EVENT REPORT (LER)					
FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)
VERMONT YANKEE NUCLEAR POWER CORPORATION	05000271	YEAR	SEQUENTIAL NUMBER	REV #	
		95	-- 014 --	00	03 OF 05

TEXT (If more space is required, use additional copies of NRC Form 366A) (17)

On 08/17/95, the formation of a fourth independent, multi-discipline team was announced. This team is tasked with performing a formal root cause analysis of the subject Appendix "R" events, and is scheduled to be fully assembled by 08/28/95.

### CAUSE OF EVENT

The root cause of these events has not yet been determined. A fourth independent, multi-discipline team is currently being established to perform a detailed review of the most recent Appendix "R" events to determine root and contributing causes. This Root Cause Analysis team is scheduled to begin investigations on 08/28/95, with a formal evaluation report expected by 09/08/95. A supplement to this LER will be submitted documenting their findings.

### ANALYSIS OF EVENT

Plant fire protection systems and barriers are classified Non-Nuclear Safety. However, they protect and separate various areas containing safety related, safe shutdown equipment to ensure the reactor can be brought to and maintained in "cold shutdown" in the event of any analyzed in-plant fire. Although the events detailed in this report are significant in that they involved non-compliance with a regulatory licensing requirement, no equipment or systems have been rendered inoperable as a result of the identified conditions. The conditions involve deficiencies in some of the features credited for providing compliance with the specific requirements of 10CFR50 Appendix "R" for which compensatory measures have been taken. These measures supplement the normal fire detection and protection features, and include: continuous and roving firewatches, the limiting of combustible materials in the affected areas, and the application of additional controls to restrict hot work in these areas. In each case, as Vermont Yankee identified deficiencies in the implementation of Appendix "R" requirements, the NRC was promptly informed of the issues and corresponding compensatory measures that were put in place until the deficiencies are fully resolved. Since the conditions represented non-compliance with a regulatory requirement, it was recognized that NRC involvement was required. Vermont Yankee has established periodic dialogue with the NRC and will continue to provide frequent updates of the status of Appendix "R" issues.

With regard to recent industry concerns associated with TSI Thermo-Lag material, Vermont Yankee no longer relies on this type of fire wrap for meeting Appendix "R" safe shutdown requirements. Therefore, this industry issue does not impact the recently identified Appendix "R" issues at the plant.

### CORRECTIVE ACTIONS

#### Immediate:

1. Compensatory measures consisting of firewatches, equipment monitoring, administrative controls and enhanced awareness of potential Appendix "R" vulnerabilities have been put in place. (Status: See Note 1)



NRC Form 366 U.S. NUCLEAR REGULATORY COMMISSION (4-95)		APPROVED BY OMB NO. 3150-0104 EXPIRES 04/30/98 ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS MANDATORY INFORMATION COLLECTION REQUEST: 50.0 HRS. REPORTED LESSONS LEARNED ARE INCORPORATED INTO THE LICENSING PROCESS AND FED BACK TO INDUSTRY. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE INFORMATION AND RECORDS MANAGEMENT BRANCH (T-6 F33), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555-0001, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.		
LICENSEE EVENT REPORT (LER)				
FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)		PAGE (3)
		YEAR	SEQUENTIAL NUMBER	REV #
VERMONT YANKEE NUCLEAR POWER CORPORATION	05000271	95	-- 014 --	00
				04 OF 05

TEXT (If more space is required, use additional copies of NRC Form 366A) (17)

- An Operations Standing Order has been issued to provide details of the conditions and specify operator actions for response to particular fire scenarios in the areas determined to be vulnerable.  
(Status: See Note 1)

[Note 1: Immediate Corrective Actions 1 and 2 have been instituted to ensure that the intent of 10CFR50 Appendix "R" is satisfied. These measures will be adjusted as necessary upon identification of any additional concerns.]

#### Short Term:

- A Self Assessment team has been assembled to ensure any additional vulnerabilities are promptly identified. The team will review the Vermont Yankee Safe Shutdown Capability Analysis to verify that key assumptions and conclusions for each fire zone are acceptable. This will include design, procedural, licensing, staffing, and training aspects. The Team consists of five senior personnel, with diverse backgrounds, from Vermont Yankee, Yankee Atomic and external organizations, none of whom had significant involvement in the original program development. The Self Assessment began on 08/07/95, and is scheduled to be completed by 08/25/95.
- An Evaluation team has been established for review of concerns, operability considerations, compensatory measures, procedures, and analytical solutions. The team was established on 07/28/95 and will remain in place for the duration necessary to evaluate any findings of the Self Assessment.
- A Repair team was established on 07/28/95 to evaluate conceptual designs that may be required for resolution of some of the identified Appendix "R" deficiencies.
- An independent, multi-discipline Root Cause Analysis team is being formed to determine root and contributing causes of these events. This team is scheduled to be fully assembled on 08/28/95, with a formal evaluation report expected by 09/08/95.

#### Long Term:

- Engineering will reassess the need for more explicit operator procedures for all fire zones relative to the Safe Shutdown Capability Analysis. (Expected Completion Date: November 1995)
- Full compliance with Appendix "R" requirements, without the need for crediting the compensatory measures detailed in this report, will be achieved by no later than the end of the 1996 Refueling Outage. (Expected Completion Date: Fall 1996 Refueling Outage)
- A supplement to this LER will be submitted to document the findings of the Root Cause Analysis task team. Based on task team investigations, additional corrective actions will be detailed in the LER supplement, as required. (Expected Completion Date: October 1995)

NRC Form 366 U.S. NUCLEAR REGULATORY COMMISSION (4-95)		APPROVED BY OMB NO. 3150-0104 EXPIRES 04/30/98 ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS MANDATORY INFORMATION COLLECTION REQUEST: 50.0 HRS. REPORTED LESSONS LEARNED ARE INCORPORATED INTO THE LICENSING PROCESS AND FED BACK TO INDUSTRY. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE INFORMATION AND RECORDS MANAGEMENT BRANCH (T-6 F33), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555-0001, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.	
LICENSEE EVENT REPORT (LER)			
FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)	
		YEAR	SEQUENTIAL NUMBER
VERMONT YANKEE NUCLEAR POWER CORPORATION	05000271	95	-- 014 -- 00
		PAGE (3)	
		05 OF 05	

TEXT (If more space is required, use additional copies of NRC Form 366A) (17)

### ADDITIONAL INFORMATION

Similar events related to the implementation of 10CFR50, Appendix "R" were reported to the Commission under the following Licensee Event Reports:

- LER 93-01 "Degraded vital fire barriers due to inadequate documentation of assumptions and inadequate procedures"
- LER 94-11 "Failure to properly identify all areas requiring emergency lighting units in accordance with 10CFR50 Appendix R, Section III.J"
- LER 95-03 "Failure to provide required emergency lighting in an area in accordance with 10CFR50 Appendix R, Section III.J due to a failure in the management system."
- LER 95-04 "Incomplete repair of inoperable vital fire barrier penetration fire seal."

It is recognized that the events of this report are of concern when considered in conjunction with previous weaknesses in the fire protection and Appendix "R" areas. As a result of the recently combined Triennial/Annual Fire Protection Program Audit, a Fire Protection Program Improvement Team has been formed to assess the overall program and review the Fire Protection program base documents against the current regulatory documents. In addition, considerable improvement efforts were already underway in the SSCA as a result of the corrective actions from previously identified fire barrier and lighting issues. The findings of the task teams will be considered together with the other ongoing efforts, in determining the actions required to ensure continual improvement in the fire protection program.