

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

June 22, 1983

Office of Environmental Programs
Waste Management Administration
201 West Preston Street
Baltimore, Maryland 21201

Attention: Mr. Barry Schmidt


Re: Maryland State Discharge
Permit No. 74-DP-0187 and
NPDES Permit No. MD 0002399

Dear Mr. Schmidt:

On June 21, 1983, outfall 001, monitoring point 101 experienced a total residual chlorine of about 2.0 ppm, which is greater than the specification of 0.5 ppm. This condition existed for about 4 1/2 hours due to the air binding of the pump used to add the dechlorinating agent. The pump was vented and returned to service. Due to the infrequency and unpredictability of this event, no further corrective action is deemed necessary.

The matter had been communicated to you by telephone on June 21, 1983. Please feel free to call if you have any further questions.

Very truly yours,



L. B. Russell
Plant Superintendent

BFS/njv