

**North
Atlantic**

North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874
(603) 474-9521, Fax (603) 474-2987

The Northeast Utilities System

Ted C. Feigenbaum
Senior Vice President &
Chief Nuclear Officer

NYN- 95064

August 25, 1995

United States Nuclear Regulatory Commi on
Washington, D.C. 20555

Attention: Document Control Desk

References: (a) Facility Operating License No. NPF, Docket No. 50-443
(b) North Atlantic Letter NYN-95011, dated January 30, 1995, "Response to Request for Additional Information Regarding Steam Generator Tube Mechanical Plugs"

Subject: Action Plan to Respond to Steam Generator Tube Mechanical Plug Removal


Gentlemen:

North Atlantic Energy Service Corporation, (North Atlantic) stated in their January 30, 1995 letter [Reference (b)] to the NRC that a review of Addendum 3 of WCAP-12244, Rev. 3, would be performed and the results of the review would be submitted to the NRC 30 days prior to the next refueling outage. This letter provides that response.

The review was performed on Westinghouse WCAP-12245, Rev. 3, Addendum 4, titled "Addendum 4 to Steam Generator Tube Plug Integrity Summary Report". The report recommends that each utility implement a proactive, graduated approach for plug remedial action over the next five years. North Atlantic has been proactive in the replacement of Alloy 600 mechanical plugs since this issue first was identified. As identified in North Atlantic letter NYN-95011, [Reference (b)], Seabrook Station currently has six Alloy 600 mechanical tube plugs installed. North Atlantic plans to remove the one remaining cold leg Alloy 600 mechanical plug in Steam Generator "A" during the upcoming refueling outage, (ORO4), scheduled for November 1995. The remaining five Alloy 600 mechanical tube plugs are in Steam Generator's "B" and "C" cold legs and are scheduled to be removed during the next refueling outage, (ORO5), scheduled for 1997.

Should you have any questions regarding this matter please contact Mr. James M. Peschel, Regulatory Compliance Manager, at (603) 474-9521, extension 3772.

Very truly yours,


Ted C. Feigenbaum

200104

TCF:TGP/act

9508290157 950825
PDR ADOCK 05000443
P PDR

Ado

United States Nuclear Regulatory Commission
Attention: Document Control Desk

August 25, 1995
Page two

cc: Mr. Thomas T. Martin
Regional Administrator
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. John B. Macdonald
NRC Senior Resident Inspector
P.O. Box 1149
Seabrook, NH 03874