

Thomas J. Martin
Vice President
Engineering and Construction

Public Service Electric and Gas Company 80 Park Plaza Newark, N.J. 07101 201/430-8316

May 25, 1984

Dr. Thomas E. Murley, Administrator
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Dr. Murley:

NRC IE BULLETIN NO. 83-06, DATED JULY 22, 1983
MATERIALS SUPPLIED BY TUBE-LINE CORPORATION
HOPE CREEK GENERATING STATION

The following final report is provided in response to the
subject Bulletin.

Responses have been received from all suppliers that
furnished ASME Section III fittings for the Hope Creek
Project. Based on this input and our on-site investigation,
we have established that:

- Twenty-four carbon steel flanges supplied by Tube-Line were installed on our Emergency Diesel Generators by Colt Industries;
- 578 fittings were received from two suppliers on four bulk purchase orders; and
- No Tube-Line fittings, beyond the twenty-four described above, have been identified as installed in safety related systems.

Nonconformance Reports have been issued to control and document the disposition of those materials received on the four bulk purchase orders. These fittings have been identified as installed in non-safety related systems, removed from inventory or determined to be missing.


8406120443 840
PDR ADOCK 05000354
Q PDR

1/0 IE. 11

The heat numbers of those items identified as missing have been added to the checklist to be used during N-5 data package review. Items identified during package review as having these heat numbers shall be cut out and replaced with acceptable fittings. This administrative control will assure that the missing nonconforming fittings have not been installed in any ASME Section III system.

Colt Industries utilized twenty-four Tube-Line flanges in the manufacture of our Emergency Diesel Generators. The use of these flanges for their intended service is acceptable in accordance with ASME Code Case N-242 which is referenced in the applicable specification.

Very truly yours,



C Office of Inspection and Enforcement
Division of Reactor Construction Inspection
Washington, D. C. 20555

NRC Resident Inspector - Hope Creek
P. O. Box 241
Hancocks Bridge, NJ 08038