



**ENTERGY**

**Entergy Operations, Inc.**

P.O. Box B  
Kilona, LA 70066  
Tel 504 739 6774

**R. F. Burski**

Director,  
Nuclear Safety  
Waterford 3

**W3F1-95-0139**

**A4.05**

**PR**

**August 30, 1995**

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Subject: Waterford 3 SES  
Docket No. 50-382  
License No. NPF-38  
Request for Additional Information Regarding  
Technical Specification Change Request NPF-38-116

Gentlemen:

By letter dated July 18, 1991, as supplemented by letters dated March 16, 1994, December 2, 1994 and March 9, 1995, Waterford 3 proposed a change to Technical Specification (TS) 3/4.7.6, "Control Room Air Conditioning System."

Modifications to the proposed TS have been incorporated as a result of several discussions with the NRC review staff. These modifications are an effort to provide clarification that support intent of the proposed specifications and provide consistency with existing specifications. Where clarification was determined necessary to further define the intent of the proposed Limiting Conditions for Operation (LCOs), the proposed TS were modified conservatively such that the no significant hazards determination provided with the original submittal remains valid. The modifications are described herein and appear in Attachment A.

Description

The LCO requirements and ACTIONS for proposed specifications 3.7.6.2 and 3.7.6.4 have been modified to be consistent with the revised standard TS (NUREG 1432) and existing TS 3.7.6 during MODES 5 and 6.

9508310330 950830  
PDR ADOCK 05000382  
P PDR

A0031

Request for Additional Information Regarding Technical Specification Change

Request NPF-38-116

W3F1-95-0139

Page 2

August 30, 1995


ACTIONS a and b of proposed specification 3.7.6.3 have been revised by removing the reference to control room temperature. Surveillance 4.7.6.3.a assures compliance with specified control room temperature.

The asterisk and associated footnote concerning an allowed breach in the control room envelope have been removed from proposed specification 3.7.6.5. This provision is now addressed in revised ACTION STATEMENT d.2.a. ACTION STATEMENT d.2.b is intended to address a situation when the control room envelope is inoperable due to failing Surveillance 4.7.6.5.a at power. ACTION STATEMENT d.2.c is modified to remove the shutdown requirement.

BASES 3/4.6.4 is modified to include clarification information concerning the provisions and restrictions of ACTION STATEMENT d.2.a.

If you should have any questions concerning the above, please contact Paul Caropino at (504) 739-6692.

Very truly yours,



R.F. Burski  
Director  
Nuclear Safety

RFB/PLC/ssf  
Attachment

cc: L.J. Callan (NRC Region IV), C.P. Patel (NRC-NRR),  
R.B. McGehee, N.S. Reynolds, NRC Resident Inspectors Office,  
Administrator Radiation Protection Division (State of  
Louisiana), American Nuclear Insurers

W3F1-95-0139  
ATTACHMENT A