

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER * 400 NORTH OLIVE STREET, L.B. 81 * DALLAS, TEXAS 75201

BILLY R. CLEMENTS
VICE PRESIDENT, NUCLEAR OPERATIONS

June 4, 1984
TXX-4188

Mr. E. H. Johnson, Chief
Reactor Project Branch 1
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

Docket Nos. 50-445
50-446

COMANCHE PEAK STEAM ELECTRIC STATION
CURTAIN FIRE DAMPERS
QA FILE: CP-84-08, SDAR-132
FILE NO.: 10110

Dear Mr. Johnson:

On March 9, 1984 we verbally informed your Mr. D. Hunnicutt of a discrepancy with the installation of curtain fire dampers without proper provisions for thermal expansion. We have previously submitted an interim report logged TXX-4140, dated March 30, 1984.

We are continuing our evaluation and anticipate completion by August 13, 1984.

Very truly yours,

Billy Clements

BRC:tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection and Enforcement - (15 copies)
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8406120519 840604
PDR ADOCK 05000445
S PDR