

Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72801
Tel 501-858-4888

Jerry W. Yelverton
Vice President
Operations AND

August 25, 1995

2CAN089505

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Units 1 and 2
Docket Nos. 50-313 and 50-368
License Nos. DPR-51 and NPF-6
Revised Technical Specifications Change Request Regarding
Reactor Coolant Pump Flywheel Inspections

Gentlemen:

On April 4, 1995, Entergy Operations submitted proposed technical specification (TS) changes (0CAN049504) which would delete the requirements for inservice inspections (ISI) of reactor coolant pump (RCP) flywheels at Arkansas Nuclear One, Unit 1 (ANO-1), and Arkansas Nuclear One, Unit 2 (ANO-2). These changes were submitted as a lead plant submittal for the Combustion Engineering Owners Group since the changes were determined to be generic to all pressurized water reactors with TS requirements for ISI of RCP flywheels.

Since our initial submittal, the staff has communicated that the generic implications of the total deletion of these inspections could not be resolved prior to the next scheduled flywheel inspection (ANO-2 refueling outage 2R11). Therefore, in order to obtain relief for the next inspection, the attached change is submitted for your review and approval. This change would allow Entergy Operations to delay the ultrasonic volumetric examination of the flywheel for RCP 2P32A for one cycle. Because this change is more conservative than the entire deletion of all flywheel examinations proposed in our April 4, 1995, submittal, the discussions and no significant hazards determination included in the original submittal remain bounding.

Entergy Operations requests that the effective date for this proposed change be within 30 days of issuance of the amendment to allow for distribution and procedural revisions necessary to implement the change. Although this request is neither exigent nor emergency, your prompt review is requested prior to 2R11, which is scheduled to begin on September 22, 1995.

9509010318 950825
PDR ADDCK 05000313
P PDR

ADD 11

Very truly yours,


JWY/jjd
JWY/jjd

attachments

To the best of my knowledge and belief, the statements contained in this submittal are true.

SUBSCRIBED AND SWORN TO before me, a Notary Public in and for Johnson County and the State of Arkansas, this 25 day of August, 1995.

Juana M. Tapp
Notary Public
My Commission Expires 11-8-2000



cc: Mr. Leonard J. Callan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

Mr. George Kalman
NRR Project Manager Region IV/ANO-1 & 2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Ms. Greta Dicus
Arkansas Department of Health
Division of Radiation Control
and Emergency Management
4815 West Markham Street
Little Rock, AR 72205

PROPOSED ANO-2 TECHNICAL SPECIFICATION CHANGES