



Wisconsin Electric POWER COMPANY
231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

June 7, 1984

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. NUCLEAR REGULATORY COMMISSION
Washington, D. C. 20555

Attention: Mr. J. R. Miller, Chief
Operating Reactors, Branch 3

Gentlemen:

DOCKET NOS. 50-266 AND 50-301
MODIFICATION TO TECHNICAL SPECIFICATION CHANGE REQUEST 96
TMI BACKFIT SPECIFICATIONS
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

In a letter dated February 29, 1984, Wisconsin Electric Power Company, licensee for the Point Beach Nuclear Plant, Units 1 and 2, applied for amendments to Facility Operating Licenses DPR-24 and DPR-27 to incorporate changes into the Point Beach Nuclear Plant Technical Specifications. These changes were primarily concerned with accident monitoring instrumentation which is being installed in response to NUREG-0737. Proposed Technical Specification page changes were included with that letter.

Subsequent to our transmittal of that request, we have determined that the proposed specification regarding the reactor coolant gas vent system, specification 15.3.1.A.7, is not as clear as it could be and should be modified. We have also determined that an error was made in the surveillance specification for the containment hydrogen monitor, Item 41 of Table 15.4.1-1, and a correction should be made. Specifically, the sample gas for calibration of the hydrogen monitor has concentrations of 2% and 6% hydrogen, not 1% and 4% as originally proposed; and the calibration frequency should be listed as "R/Q", with the electronic calibration completed each refueling interval, and the gas calibration done quarterly.

We have reviewed the 10 CFR 50.91 significant hazards consideration determination provided with our February 29 application. The modifications to our change request provided with this letter do not change the basis or conclusion of that determination.

840614003B 840607
PDR ADOCK 05000266
P


Adk
11

Mr. H. R. Denton, Director -2-

June 7, 1984

We have enclosed three signed originals and 40 copies of this modification to Technical Specification Change Request 96; the revised Technical Specification pages supersede those corresponding pages provided with our February 29 letter. Please contact me if you have any questions concerning these changes.

Very truly yours,




Vice President-Nuclear Power

C. W. Fay

Attachment

Copies to NRC Resident Inspector
C. F. Riederer, PSCW

Subscribed and sworn to before me
this 11th day of June 1984.


Notary Public, State of Wisconsin

My commission expires permanently