



GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

C321-92-2035
January 29, 1992

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:


Subject: Oyster Creek Nuclear Generating Station (OCNGS)
Docket No. 50-219
Response to Generic Letter 91-11
Resolution of Generic Issues 48 and 49

GPU Nuclear Corporation (GPUN) has reviewed the guidance attached to Generic Letter 91-11 and evaluated its requirements using a multi-disciplinary review process. Equipment, procedures, and other design documents were reviewed and evaluated in accordance with the recommended actions of the Generic Letter.

As a result, several procedures were revised to include time limitations for normal and/or alternate power supplies to 120V 1E vital instrument buses to be out of service. [Generic Issue No. 48] Additionally, review of the existing station procedures for control of interlocks to Class 1E Tie Breakers found that the administrative controls, currently in place, conform to the GL 91-11 guidelines. [Generic Issue No. 49]


Therefore, GPUN does hereby certify that the Oyster Creek Nuclear Generating Station has implemented procedures which conform to the guidance contained in the Enclosure to Generic Letter 91-11.

Sincerely,


for J. J. Barton
Vice President and Director
Oyster Creek

JRB/GMG
cc: Director, Project Directorate I-4
Region I, Administrator
NRC Project Manager
Senior NRC Resident Inspector, OCNGS

Sworn to and subscribed before me this 29th day of January, 1992.



JUDITH M. CROWE
Notary Public of New Jersey
My Commission Expires 11/25/95

9202050149 920129
PDR ADOCK 05000219
P PDR

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

040017
A027 1/0