

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of) UNIT NO. 2
) Docket No. 50-412
Duquesne Light Company) License No. NPF-73
Beaver Valley Power Station)

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the technical specifications set forth in Appendix A to this license be amended to delete the associated process flow rate monitor operability requirements, as specified in Tables 3.3-13 and 4.3-13, for the gaseous effluent monitors 2RMQ-RQ-301, 2RMQ-RQ-303, and 2HVL-RQ-112.

The proposed technical specification change is set forth in Attachment A to this application. A safety analysis and no significant hazard evaluation are set forth in Attachment B. Typed replacement pages for the technical specifications are included in Attachment C. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.93.

WHEREFORE, Applicant respectfully requests that Appendix A to the operating license be amended in the form attached hereto as Attachment A.


Duquesne Light Company

By J.D. Sieber
J.D. Sieber
Vice President
Nuclear Group

Subscribed and sworn to before me

on this 31 day of January, 1992

Shella M. Fattore



ATTACHMENT A

Beaver Valley Power Station, Unit No. 2
Proposed Technical Specification Change No. 61

Revise the Technical Specification as follows:

Remove Page

3/4 3-67
3/4 3-68
3/4 3-71
3/4 3-72

Insert Page

3/4 3-67
3/4 3-68
3/4 3-71
3/4 3-72