



**New York Power
Authority**

Harry P. Salmon, Jr.
Site Executive Officer

August 29, 1995
JAFP-95-0390

United States Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

SUBJECT: DOCKET NO. 50-333
LICENSEE EVENT REPORT: LER-95-006-01:


Reactor Safety Relief Valve Setpoint Drift

Dear Sir:

This report is submitted in accordance with 10CFR50.73
(a)(2)(i).

This supplement provides the results of an analysis performed on the as-found actuation pressures of eleven safety relief valves removed and tested during the 1994/1995 refueling outage. The analysis was performed to determine the margin to the reactor vessel pressure safety limit based on these as-found actuation pressures. Questions concerning this report may be addressed to Mr. Gordon Brownell at (315) 349-6360.

Very truly yours,



HARRY P. SALMON, JR.

HPS:GJB:tlc

Enclosure

cc: USNRC, Region I
USNRC Resident Inspector
INPO Records Center

IE22
11