

ADMINISTRATIVE CONTROLSFACILITY STAFF (CONTINUED)

- d. An individual qualified in radiation protection procedures shall be on site when fuel is in the reactor. (Table 6.2-1)
- e. ALL CORE ALTERATIONS after the initial fuel loading shall be directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
- f. A site Fire Brigade of at least 5 members shall be maintained onsite at all times. (Table 6.2-1) The Fire Brigade shall not include 2 members of the minimum shift crew necessary for safe shutdown of the unit or any personnel required for other essential functions during a fire emergency.
- g. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions. These procedures should follow the general guidance of the NRC Policy Statement on working hours (Generic Letter No. 82-12).

6.3 FACILITY STAFF QUALIFICATIONS

- 6.3.1 Each member of the facility staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for:
- a. If the Operations Manager does not hold a senior reactor operator license for Millstone Unit No. 2, then the Operations Manager shall have held a senior reactor operator license at a Pressurized Water Reactor ~~other than Millstone Unit No. 2~~ and an individual serving in the capacity of the Assistant Operations Manager shall hold a senior reactor operator license for Millstone Unit No. 2.
  - b. The Shift Technical Advisor (STA) who shall meet the requirements of Specification 6.3.1.b.1 or 6.3.1.b.2.
    - 1. Dual-role individual: Must hold a senior reactor operator's license at Millstone Unit No. 2, meet the STA training criteria of NUREG-0737, Item I.A.1.1, and meet one of the following educational alternatives:
      - a. Bachelor's degree in engineering from an accredited institution;
      - b. Professional Engineer's license obtained by the successful completion of the PE examination;

Docket No. 50-336  
B15213

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

Proposed Revision to Technical Specifications  
Administrative Controls - Section 6

Retyped Page

August 1995

## ADMINISTRATIVE CONTROLS

### FACILITY STAFF (CONTINUED)

- d. An individual qualified in radiation protection procedures shall be on site when fuel is in the reactor. (Table 6.2-1)
- e. ALL CORE ALTERATIONS after the initial fuel loading shall be directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
- f. A site Fire Brigade of at least 5 members shall be maintained onsite at all times. (Table 6.2-1) The Fire Brigade shall not include 2 members of the minimum shift crew necessary for safe shutdown of the unit or any personnel required for other essential functions during a fire emergency.
- g. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions. These procedures should follow the general guidance of the NRC Policy Statement on working hours (Generic Letter No. 82-12).

### 6.3 FACILITY STAFF QUALIFICATIONS

- 6.3.1 Each member of the facility staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for:
- a. If the Operations Manager does not hold a senior reactor operator license for Millstone Unit No. 2, then the Operations Manager shall have held a senior reactor operator license at a Pressurized Water Reactor and an individual serving in the capacity of the Assistant Operations Manager shall hold a senior reactor operator license for Millstone Unit No. 2.
  - b. The Shift Technical Advisor (STA) who shall meet the requirements of Specification 6.3.1.b.1 or 6.3.1.b.2.
    - 1. Dual-role individual: Must hold a senior reactor operator's license at Millstone Unit No. 2, meet the STA training criteria of NUREG-0737, Item I.A.1.1, and meet one of the following educational alternatives:
      - a. Bachelor's degree in engineering from an accredited institution;
      - b. Professional Engineer's license obtained by the successful completion of the PE examination;