

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

- (5) Operation beyond the end-of-cycle (all rods out condition) thermal power is limited to seventy (70) percent minimum. Increasing core power level via reduced feedwater heating, once operation in the coastdown mode has begun, is not permitted unless the licensee has performed an analysis of this operating condition that confirms that this condition is bounded by the analysis for the particular cycle of operation.

3. This license is subject to the following conditions for the protection of the environment:
- A. If the actual milk sample measurements taken at the nearby farms in accordance with the Technical Specifications, predict a dose to a child's thyroid, based on actual combined operation of Unit 2 and 3, that exceeds 15 mrem/year, licensees shall install for operation no later than the next refueling cycle for each unit the necessary equipment to reduce the projected dose to such levels.
 - B. To the extent matters related to thermal discharges are treated therein, operation of Peach Bottom Atomic Power Station Unit 2 will be governed by NPDES Permit No. PA 0009733, as now in effect and as hereafter amended. Questions pertaining to conformance thereto shall be referred to and shall be determined by the NPDES Permit issuing or enforcement authority, as appropriate.
 - C. In the event of any modification of the NPDES Permit related to thermal discharges or the establishment (or amendment) of alternative effluent limitations established pursuant to Section 316 of the Federal Water Pollution Control Act, the licensees shall inform the NRC and analyze any associated changes in or to the Station, its components, its operation or in the discharge of effluents therefrom. If such change would entail any modification to this license, or any technical specifications which are part of this license, or present an unreviewed safety question or involve an environmental impact different than analyzed in the Final Environmental Statement, the licensees shall file with the NRC, as applicable, an appropriate analysis of any such change on facility safety, and/or an analysis of any such change on the environmental impacts and on the overall cost-benefit balance for facility operation set forth in the Final Environmental Statement and a request for an amendment to the operating license, if required by the Commission's regulations. As used in this Condition 3.(d), Final Environmental Statement means the NRC Staff Final Environmental Statement related to Operation of Peach Bottom Atomic Power Station Units Nos. 2 and 3 dated April 1973, as modified by (1) the Initial Decision of the Atomic Safety and Licensing Board dated September 14, 1973, (2) the Supplemental Initial Decision of the Atomic Safety and Licensing Board dated June 14, 1974, (3) the Decision of the Atomic Safety and Licensing Appeal Board dated July 5, 1974, (4) the Memorandum and Order of the Commission dated August 8, 1974, (5) any further modification resulting from further review by the Appeal Board and by