



Illinois Power Company
Clinton Power Station
P.O. Box 678
Clinton, IL 61727
Tel 217 535-8881

U-602492
L30-95(09-06)-LP
8E.100c

September 6, 1995

10CFR50.36

Docket No. 50-461

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Clinton Power Station, Unit 1
Facility Operating License NPF-62
August 1995 Monthly Operating Report

Dear Sir:

Please find in Attachment 1 the Monthly Operating Report for Clinton Power Station, Unit 1, for the period ending August 31, 1995.

Sincerely yours,

Richard F. Phares
Director - Licensing

MCH/krm

Attachment

cc: NRC Region III Regional Administrator
NRC Resident Office, V-690
Illinois Department of Nuclear Safety

9509110170 950831
PDR ADOCK 050004
R PDR

110066

JE24

CHALLENGES TO MAIN STEAM SAFETY/RELIEF VALVES

Month August 1995

None

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-461
UNIT Clinton 1
DATE 08/31/95
COMPLETED BY M. C. Hollon
TELEPHONE (217) 935-8881 X3537

MONTH August 1995

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>900</u>
2	<u>903</u>
3	<u>903</u>
4	<u>904</u>
5	<u>907</u>
6	<u>905</u>
7	<u>906</u>
8	<u>905</u>
9	<u>905</u>
10	<u>905</u>
11	<u>905</u>
12	<u>904</u>
13	<u>879</u>
14	<u>901</u>
15	<u>900</u>
16	<u>899</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>899</u>
18	<u>899</u>
19	<u>900</u>
20	<u>900</u>
21	<u>902</u>
22	<u>904</u>
23	<u>905</u>
24	<u>905</u>
25	<u>904</u>
26	<u>903</u>
27	<u>902</u>
28	<u>901</u>
29	<u>899</u>
30	<u>898</u>
31	<u>901</u>

OPERATING DATA REPORT

DOCKET NO. 50-461
UNIT Clinton 1
DATE 08/31/95
COMPLETED BY M. C. Hollon
TELEPHONE (217) 935-8881 X3537

OPERATING STATUS

1. REPORTING PERIOD: August 1995 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2894
MAX. DEPEND. CAPACITY (MDC) (MWe-Net): 930
DESIGN ELECTRICAL RATING (MWe-Net): 933
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL...	<u>744.0</u>	<u>4,550.9</u>	<u>50,302.8</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
7. HOURS GENERATOR ON LINE.....	<u>744.0</u>	<u>4,451.6</u>	<u>48,876.0</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>4.0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)...	<u>2,160,540</u>	<u>11,893,592</u>	<u>130,359,790</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>702,170</u>	<u>3,894,038</u>	<u>43,050,989</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)...	<u>670,862</u>	<u>3,708,342</u>	<u>40,984,520</u>
12. REACTOR SERVICE FACTOR.....	<u>100.0%</u>	<u>78.0%</u>	<u>73.9%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>78.0%</u>	<u>73.9%</u>
14. UNIT SERVICE FACTOR.....	<u>100.0%</u>	<u>76.3%</u>	<u>71.8%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>76.3%</u>	<u>71.8%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>97.0%</u>	<u>68.4%</u>	<u>64.7%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>96.6%</u>	<u>68.2%</u>	<u>64.5%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>0.0%</u>	<u>3.4%</u>	<u>8.7%</u>

19. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, DURATION OF EACH):

None

20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-461
UNIT Clinton 1
DATE 08/31/95
COMPLETED BY M. C. Hollon
TELEPHONE (217) 935-8881 X3537

REPORT MONTH August 1995

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON(1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
-----	------	-----------------------------------	---------------------	-----------	---	--------------------------------

NONE

- (1) Reason
A-Equipment Failure (explain), B-Maintenance or Test, C-Refueling, D-Regulatory Restriction,
E-Operator Training & License Examination, F-Administrative, G-Operational Error (explain),
H-Other (explain)
- (2) Method
1-Manual, 2-Manual Scram, 3-Automatic Scram, 4-Other (explain)